



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 07-Sep-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 06-Sep-22

[CHPH 5X50 MW]

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	6-Sep-22	0:00:00	6-Sep-22	24:00:00	24:00:00	52.00	1.221	Today (i.e. 07.09.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	6-Sep-22	0:00:00	6-Sep-22	24:00:00	24:00:00	51.00	1.201	
3	6-Sep-22	0:00:00	6-Sep-22	0:00:00	0:00:00	0.00	0.000	
4	6-Sep-22	0:00:00	6-Sep-22	24:00:00	24:00:00	52.00	1.217	
5	6-Sep-22	0:00:00	6-Sep-22	24:00:00	24:00:00	50.00	1.161	

[RBPH 6X200 MW]

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	6-Sep-22	0:00:00	6-Sep-22	24:00:00	24:00:00	207	4.916	Today (i.e. 07.09.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs
2	6-Sep-22	0:00:00	6-Sep-22	24:00:00	24:00:00	206	4.912	
3	6-Sep-22	0:00:00	6-Sep-22	24:00:00	24:00:00	206	4.900	
4	6-Sep-22	0:00:00	6-Sep-22	24:00:00	24:00:00	206	4.944	
5	6-Sep-22	0:00:00	6-Sep-22	24:00:00	24:00:00	206	4.972	
6	6-Sep-22	0:00:00	6-Sep-22	24:00:00	24:00:00	206	4.910	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.800	29.554	34.354
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	28.692	177.194	205.886
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 7-Sep-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 137.17 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 76578 Cusec 187.35 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 65945 Cusec 161.34 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
17597	601

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
612	5000	17460	17790	43155	496	32.50



(Signature)
7/9/22

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil

(Signature)
7/9/22
J E (EMC)