



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 08-Sep-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 07-Sep-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-Sep-22	0:00:00	7-Sep-22	24:00:00	24:00:00	52.00	1.236	Today (i.e. 08.09.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	7-Sep-22	0:00:00	7-Sep-22	24:00:00	24:00:00	50.00	1.197	
3	7-Sep-22	0:00:00	7-Sep-22	0:00:00	0:00:00	0.00	0.000	
4	7-Sep-22	0:00:00	7-Sep-22	24:00:00	24:00:00	52.00	1.229	
5	7-Sep-22	0:00:00	7-Sep-22	24:00:00	24:00:00	50.00	1.161	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	7-Sep-22	0:00:00	7-Sep-22	24:00:00	24:00:00	207	4.920	Today (i.e. 08.09.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs
2	7-Sep-22	0:00:00	7-Sep-22	24:00:00	24:00:00	206	4.922	
3	7-Sep-22	0:00:00	7-Sep-22	24:00:00	24:00:00	206	4.884	
4	7-Sep-22	0:00:00	7-Sep-22	24:00:00	24:00:00	206	4.956	
5	7-Sep-22	0:00:00	7-Sep-22	24:00:00	24:00:00	206	4.976	
6	7-Sep-22	0:00:00	7-Sep-22	24:00:00	24:00:00	206	4.914	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.823	29.572	34.395
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	33.515	206.766	240.281
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 8-Sep-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 137.27 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 79486 Cusec 194.47 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 66316 Cusec 162.25 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17459	612

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
615	5000	17794	17773	43543	499	32.50



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE
8/9/22

Arochita Karamge
J.E. (EMC), NCA

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil