



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 16-Sep-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 15-Sep-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	15-Sep-22	0:00:00	15-Sep-22	24:00:00	24:00:00	52.00	1.198	Today (i.e. 16.09.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs. CHPH Unit no. 3 is under COH from 01.04.2022.
2	15-Sep-22	0:00:00	15-Sep-22	24:00:00	24:00:00	50.00	1.203	
3	15-Sep-22	14:10 21:18	15-Sep-22	14:29 21:40	0:41:00	0.00	0.012	
4	15-Sep-22	0:00:00	15-Sep-22	24:00:00	24:00:00	52.00	1.182	
5	15-Sep-22	0:00:00	15-Sep-22	24:00:00	24:00:00	50.00	1.148	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	15-Sep-22	0:00:00	15-Sep-22	24:00:00	24:00:00	206	4.884	Today (i.e. 16.09.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs
2	15-Sep-22	0:00:00	15-Sep-22	24:00:00	24:00:00	207	4.910	
3	15-Sep-22	0:00:00	15-Sep-22	24:00:00	24:00:00	206	4.884	
4	15-Sep-22	0:00:00	15-Sep-22	24:00:00	24:00:00	206	4.936	
5	15-Sep-22	0:00:00	15-Sep-22	24:00:00	24:00:00	206	4.938	
6	15-Sep-22	0:00:00	15-Sep-22	24:00:00	24:00:00	206	4.898	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN (MUs)	4.743	29.450	34.193
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	71.754	443.346	515.100
PREVIOUS DAY ACTUAL RUNNING HOURS	96:41:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 16-Sep-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.31 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 248316 Cusec 607.52 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 296495 Cusec 725.40 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17371	614

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
614	235417	17334	17005	44073	526	36.00



for Sharma
16/9/22
TE/EM/IND

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-
Nil

Prepared by
Sharma
16/9/22