



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 01-Oct-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 30-Sep-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	30-Sep-22	0:00:00	30-Sep-22	24:00:00	24:00:00	50.00	1.188	Today (i.e. 01.10.2022), 5 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	30-Sep-22	0:00:00	30-Sep-22	24:00:00	24:00:00	50.00	1.189	
3	30-Sep-22	0:00:00	30-Sep-22	24:00:00	24:00:00	50.00	1.192	
4	30-Sep-22	0:00:00	30-Sep-22	24:00:00	24:00:00	50.00	1.186	
5	30-Sep-22	0:00:00	30-Sep-22	24:00:00	24:00:00	48.00	1.125	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	30-Sep-22	0:00:00	30-Sep-22	24:00:00	24:00:00	207	4.924	Today (i.e. 01.10.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs
2	30-Sep-22	0:00:00	30-Sep-22	24:00:00	24:00:00	205	4.892	
3	30-Sep-22	0:00:00	30-Sep-22	24:00:00	24:00:00	208	4.918	
4	30-Sep-22	0:00:00	30-Sep-22	24:00:00	24:00:00	207	4.976	
5	30-Sep-22	0:00:00	30-Sep-22	24:00:00	24:00:00	206	4.954	
6	30-Sep-22	0:00:00	30-Sep-22	24:00:00	24:00:00	207	4.942	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	5.880	29.606	35.486
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	158.662	887.792	1046.454
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 1-Oct-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.64 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 73638 Cusec 180.16 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 75614 Cusec 185.00 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
21152	618

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
618	12000	21431	21236	42378	656	32.50



Handwritten signature: Hemant Pandey
J. E. (E. lect.)
EMC, NCA

(Hemant Pandey)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil