



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 02-Oct-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 01-Oct-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Oct-22	0:00:00	1-Oct-22	24:00:00	24:00:00	50.00	1.191	Today (i.e. 02.10.2022), 5 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	1-Oct-22	0:00:00	1-Oct-22	24:00:00	24:00:00	50.00	1.174	
3	1-Oct-22	0:00:00	1-Oct-22	24:00:00	24:00:00	51.00	1.203	
4	1-Oct-22	0:00:00	1-Oct-22	24:00:00	24:00:00	50.00	1.181	
5	1-Oct-22	0:00:00	1-Oct-22	24:00:00	24:00:00	47.00	1.116	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Oct-22	0:00:00	1-Oct-22	24:00:00	24:00:00	207	4.924	Today (i.e. 02.10.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs
2	1-Oct-22	0:00:00	1-Oct-22	24:00:00	24:00:00	205	4.726	
3	1-Oct-22	0:00:00	1-Oct-22	24:00:00	24:00:00	208	4.922	
4	1-Oct-22	0:00:00	1-Oct-22	24:00:00	24:00:00	207	4.980	
5	1-Oct-22	0:00:00	1-Oct-22	24:00:00	24:00:00	207	4.950	
6	1-Oct-22	0:00:00	1-Oct-22	24:00:00	24:00:00	207	4.952	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	5.865	29.454	35.319
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	5.865	29.454	35.319
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 2-Oct-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.66 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 72288 Cusec 176.86 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 68872 Cusec 168.50 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
21431	618

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
604	5583	21802	21264	42025	783	32.50

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG. CE(E&M),SSNNL,Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil

for Hemant Pandey
J.E. (Elect.)
EMC, NCA
(Hemant Pandey)
Executive Engineer (EMC)
NCA, INDORE