



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 10-Oct-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 09-Oct-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Oct-22	0:00:00	9-Oct-22	24:00:00	24:00:00	50.00	1.183 /	Today (i.e. 10.10.2022), 5 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	9-Oct-22	0:00:00	9-Oct-22	24:00:00	24:00:00	50.00	1.177 /	
3	9-Oct-22	0:00:00	9-Oct-22	24:00:00	24:00:00	51.00	1.194 /	
4	9-Oct-22	0:00:00	9-Oct-22	24:00:00	24:00:00	50.00	1.181 /	
5	9-Oct-22	0:00:00	9-Oct-22	24:00:00	24:00:00	50.00	1.125 /	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Oct-22	0:00:00	9-Oct-22	24:00:00	24:00:00	207	4.934 /	Today (i.e. 10.10.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs
2	9-Oct-22	0:00:00	9-Oct-22	24:00:00	24:00:00	205	4.878 /	
3	9-Oct-22	0:00:00	9-Oct-22	24:00:00	24:00:00	207	4.926 /	
4	9-Oct-22	0:00:00	9-Oct-22	24:00:00	24:00:00	207	4.958 /	
5	9-Oct-22	0:00:00	9-Oct-22	24:00:00	24:00:00	206	4.960 /	
6	9-Oct-22	0:00:00	9-Oct-22	24:00:00	24:00:00	207	4.936 /	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	5.860	29.592	35.452 /
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	52.700	266.396	319.096 /
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 10-Oct-22

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 138.61 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 83142 Cusec 203.41 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 83675 Cusec 204.72 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
21521 /	610 /

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
601 /	20000 /	21662 /	21403 /	42272 /	782 /	33.50 /



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG. CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil

Asphy
10/10/22
J.E. (Elect)
EMC, N.C.A.