



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 15-Oct-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 14-Oct-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	14-Oct-22	0:00:00	14-Oct-22	24:00:00	24:00:00	50.00	1.182	Today (i.e. 15.10.2022), 5 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	14-Oct-22	0:00:00	14-Oct-22	24:00:00	24:00:00	50.00	1.184	
3	14-Oct-22	0:00:00	14-Oct-22	24:00:00	24:00:00	51.00	1.191	
4	14-Oct-22	0:00:00	14-Oct-22	24:00:00	24:00:00	50.00	1.182	
5	14-Oct-22	0:00:00	14-Oct-22	24:00:00	24:00:00	47.00	1.118	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	14-Oct-22	0:00:00	14-Oct-22	24:00:00	24:00:00	207	4.892	Today (i.e. 15.10.2022), 6 SSP-RBPH M/cs are running at 9:00 hrs
2	14-Oct-22	0:00:00	14-Oct-22	24:00:00	24:00:00	206	4.884	
3	14-Oct-22	0:00:00	14-Oct-22	24:00:00	24:00:00	207	4.896	
4	14-Oct-22	0:00:00	14-Oct-22	24:00:00	24:00:00	207	4.978	
5	14-Oct-22	0:00:00	14-Oct-22	24:00:00	24:00:00	206	4.922	
6	14-Oct-22	0:00:00	14-Oct-22	24:00:00	24:00:00	207	4.938	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	5.857	29.510	35.367
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	82.025	414.484	496.509
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	144:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	144:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	144:00:00	

SSP hydrological data : at 08:00 Hrs on 15-Oct-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 138.63 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 72567 Cusec 177.54 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 69151 Cusec 169.18 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
21475	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
620	5208	21475	21247	42696	782	33.50



for Archita Karyung
J. E. (Elect),
EMC, NCA
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil