



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 30-Oct-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 29-Oct-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Oct-22	0:00:00	29-Oct-22	24:00:00	24:00:00	51.00	1.216	Today (i.e. 30.10.2022), 3 No. of SSP-CHPH M/c's are running at 9:00 hrs.
2	29-Oct-22	0:00:00	29-Oct-22	24:00:00	24:00:00	50.00	1.177	
3	29-Oct-22	0:00:00	29-Oct-22	0:00:00	0:00:00	0.00	0.000	
4	29-Oct-22	0:00:00	29-Oct-22	0:00:00	0:00:00	0.00	0.000	
5	29-Oct-22	0:00:00	29-Oct-22	24:00:00	24:00:00	49.00	1.148	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Oct-22	4:45:00	29-Oct-22	7:30:00	2:45:00	205	0.560	Today (i.e. 30.10.2022), 0 SSP-RBPH M/c is running at 9:00 hrs
2	29-Oct-22	5:00:00	29-Oct-22	7:45:00	2:45:00	205	0.566	
3	29-Oct-22	5:15 16:00	29-Oct-22	8:00 20:00	6:45:00	205	1.382	
4	29-Oct-22	5:30 16:00	29-Oct-22	8:15 20:30	6:30:00	206	1.352	
5	29-Oct-22	17:00:00	29-Oct-22	20:45:00	3:45:00	205	0.778	
6	29-Oct-22	17:15:00	29-Oct-22	21:00:00	3:45:00	205	0.772	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	3.541	5.410	8.951
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	142.180	679.328	821.508
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	26:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	89:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	13:30:00	

SSP hydrological data : at 08:00 Hrs on 30-Oct-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 137.49 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 15189 Cusec 37.16 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18242 Cusec 44.63 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
13433	612

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
611	0	14711	13291	4951	748	31.00



Rajesh Sharma
J.E. (E&T)
EMC, NCA

Copy to :

- NCA -Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 6: 22:10 Hrs on 29.10.2022 to 06:35 Hrs on 30.10.2022.

Unit No. 5: 22:15 Hrs on 29.10.2022 to 06:40 Hrs on 30.10.2022.

(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE