



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 31-Oct-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 30-Oct-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	30-Oct-22	0:00:00	30-Oct-22	20:00:00	20:00:00	51.00	1.004	Today (i.e. 31.10.2022), 3 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	30-Oct-22	0:00:00	30-Oct-22	24:00:00	24:00:00	49.00	1.169	
3	30-Oct-22	0:00:00	30-Oct-22	0:00:00	0:00:00	0.00	0.000	
4	30-Oct-22	7:00:00	30-Oct-22	24:00:00	17:00:00	51.00	0.849	
5	30-Oct-22	0:00:00	30-Oct-22	24:00:00	24:00:00	49.00	1.132	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	30-Oct-22	0:00:00	30-Oct-22	0:00:00	0:00:00	0	0.000	Today (i.e. 31.10.2022), 0 SSP-RBPH M/c is running at 9:00 hrs
2	30-Oct-22	0:00:00	30-Oct-22	0:00:00	0:00:00	0	0.000	
3	30-Oct-22	0:00:00	30-Oct-22	0:00:00	0:00:00	0	0.000	
4	30-Oct-22	0:00:00	30-Oct-22	0:00:00	0:00:00	0	0.000	
5	30-Oct-22	0:00:00	30-Oct-22	0:00:00	0:00:00	0	0.000	
6	30-Oct-22	0:00:00	30-Oct-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.154	0.000	4.154
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	146.334	679.328	825.662
PREVIOUS DAY ACTUAL RUNNING HOURS	85:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	13:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	14:00:00	

SSP hydrological data : at 08:00 Hrs on 31-Oct-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 137.43 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9516 Cusec 23.28 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 16374 Cusec 40.06 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
14710	611

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
615	0	15983	15291	1083	746	30.00



(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 3: 21:25 Hrs on 30.10.2022 to 05:40 Hrs on 31.10.2022.

Unit No. 4: 21:35 Hrs on 30.10.2022 to 05:35 Hrs on 31.10.2022.

Verified by  
Ajay Sharma,  
SE(EMC), NCA.

*(Signature)*  
31/10/22