



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 10-Nov-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 09-Nov-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Nov-22	0:00:00	9-Nov-22	24:00:00	24:00:00	50.00	1.195	Today (i.e. 10.11.2022), 5 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	9-Nov-22	0:00:00	9-Nov-22	24:00:00	24:00:00	50.00	1.177	
3	9-Nov-22	0:00:00	9-Nov-22	24:00:00	24:00:00	49.00	1.177	
4	9-Nov-22	0:00:00	9-Nov-22	24:00:00	24:00:00	50.00	1.192	
5	9-Nov-22	0:00 20:00	9-Nov-22	14:00 24:00	18:00:00	49.00	0.841	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Nov-22	15:45:00	9-Nov-22	19:15:00	3:30:00	204	0.708	Today (i.e. 10.11.2022), 0 SSP-RBPH M/C is running at 9:00 hrs
2	9-Nov-22	16:00:00	9-Nov-22	19:30:00	3:30:00	204	0.712	
3	9-Nov-22	0:00:00	9-Nov-22	0:00:00	0:00:00	0	0.000	
4	9-Nov-22	0:00:00	9-Nov-22	0:00:00	0:00:00	0	0.000	
5	9-Nov-22	16:30:00	9-Nov-22	19:45:00	3:15:00	203	0.670	
6	9-Nov-22	16:45:00	9-Nov-22	20:15:00	3:30:00	204	0.714	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	5.582	2.804	8.386
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	44.435	25.644	70.079
PREVIOUS DAY ACTUAL RUNNING HOURS	114:00:00	13:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	13:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	13:45:00	

SSP hydrological data : at 08:00 Hrs on 10-Nov-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 137.35 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 27649 Cusec 67.65 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 24480 Cusec 59.89 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
22046	609

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
611	0	22403	20752	3728	635	21.00



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 and Raj-2 lines are in service.

2. SCO Mode Detail:-
Nil

Achita Kaurwiga
J.E. (Elect.)
EMC, NCA

10/11/22