

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Nov-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 10-Nov-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Nov-22	0:00:00	10-Nov-22	24:00:00	24:00:00	50.00	1.197	Today (i.e. 11.11.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	10-Nov-22	0:00:00	10-Nov-22	24:00:00	24:00:00	50.00	1.181	
3	10-Nov-22	0:00:00	10-Nov-22	24:00:00	24:00:00	50.00	1.185	
4	10-Nov-22	0:00:00	10-Nov-22	24:00:00	24:00:00	50.00	1.185	
5	10-Nov-22	0:00:00	10-Nov-22	23:00:00	23:00:00	49.00	1.048	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Nov-22	16:15:00	10-Nov-22	19:30:00	3:15:00	203	0.630	Today (i.e. 11.11.2022), 0 SSP-RBPH M/C is running at 9:00 hrs
2	10-Nov-22	16:30:00	10-Nov-22	19:45:00	3:15:00	203	0.632	
3	10-Nov-22	0:00:00	10-Nov-22	0:00:00	0:00:00	0	0.000	
4	10-Nov-22	0:00:00	10-Nov-22	0:00:00	0:00:00	0	0.000	
5	10-Nov-22	15:30:00	10-Nov-22	19:00:00	3:30:00	204	0.684	
6	10-Nov-22	16:45:00	10-Nov-22	20:15:00	3:30:00	203	0.676	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	5.796	2.622	8.418
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	50.231	28.266	78.497
PREVIOUS DAY ACTUAL RUNNING HOURS	119:00:00	13:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	13:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	13:45:00	

SSP hydrological data : at 08:00 Hrs on 11-Nov-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 137.32 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 20832 Cusec 50.97 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 24001 Cusec 58.72 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
22402	611

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
628	0	20656	20323	3678	634	21.00



(Signature)
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 3: 20:40 Hrs on 10.11.2022 to 05:55 Hrs on 11.11.2022.

Unit No. 4: 20:45 Hrs on 10.11.2022 to 06:00 Hrs on 11.11.2022.

*Impacted by
Shankar
SE, EMC, NCA*