



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 16-Nov-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 15-Nov-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	15-Nov-22	0:00:00	15-Nov-22	24:00:00	24:00:00	50.00	1.183	Today (i.e. 16.11.2022), 5 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	15-Nov-22	0:00:00	15-Nov-22	24:00:00	24:00:00	50.00	1.183	
3	15-Nov-22	0:00:00	15-Nov-22	24:00:00	24:00:00	50.00	1.185	
4	15-Nov-22	0:00:00	15-Nov-22	24:00:00	24:00:00	51.00	1.191	
5	15-Nov-22	0:00:00	15-Nov-22	24:00:00	24:00:00	47.00	1.106	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	15-Nov-22	16:30:00	15-Nov-22	19:15:00	2:45:00	201	0.562	Today (i.e. 16.11.2022), 0 SSP-RBPH M/C is running at 9:00 hrs
2	15-Nov-22	0:00:00	15-Nov-22	0:00:00	0:00:00	0	0.000	
3	15-Nov-22	17:00:00	15-Nov-22	19:30:00	2:30:00	202	0.506	
4	15-Nov-22	17:15:00	15-Nov-22	19:45:00	2:30:00	200	0.514	
5	15-Nov-22	15:00:00	15-Nov-22	18:45:00	3:45:00	204	0.764	
6	15-Nov-22	15:15:00	15-Nov-22	19:00:00	3:45:00	202	0.756	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	5.848	3.102	8.950
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	77.263	42.586	119.849
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	15:15:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	14:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	14:30:00	

SSP hydrological data : at 08:00 Hrs on 16-Nov-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 136.54 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 2858 Cusec 6.99 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 26320 Cusec 64.39 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
22534	614

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
620	0	21614	22073	4247	614	30.00



(Signature)
(Rajesh Sharma) 16/11/22
Executive Engineer (EMC)
NCA, INDORE

Archita Kharwar
16-11-22

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

UUnit No. 2: 21:20 Hrs on 15.11.2022 to 05:35 Hrs on 16.11.2022.

Unit No. 6: 21:30 Hrs on 15.11.2022 to 05:46 Hrs on 16.11.2022.