



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 01-Dec-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 30-Nov-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	30-Nov-22	0:00:00	30-Nov-22	24:00:00	24:00:00	50.00	1.191	Today (i.e. 01.12.2022), 5 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	30-Nov-22	0:00:00	30-Nov-22	24:00:00	24:00:00	50.00	1.187	
3	30-Nov-22	0:00:00	30-Nov-22	24:00:00	24:00:00	50.00	1.193	
4	30-Nov-22	0:00:00	30-Nov-22	24:00:00	24:00:00	51.00	1.203	
5	30-Nov-22	0:00:00	30-Nov-22	24:00:00	24:00:00	49.00	1.105	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	30-Nov-22	0:00:00	30-Nov-22	0:00:00	0:00:00	0	0.000	Today (i.e. 01.12.2022), 0 SSP-RBPH M/C is running at 9:00 hrs
2	30-Nov-22	0:00:00	30-Nov-22	0:00:00	0:00:00	0	0.000	
3	30-Nov-22	0:00:00	30-Nov-22	0:00:00	0:00:00	0	0.000	
4	30-Nov-22	0:00:00	30-Nov-22	0:00:00	0:00:00	0	0.000	
5	30-Nov-22	0:00:00	30-Nov-22	0:00:00	0:00:00	0	0.000	
6	30-Nov-22	0:00:00	30-Nov-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	5.879	0.000	5.879
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	163.668	54.560	218.228
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 1-Dec-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.96 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 17082 Cusec 41.79 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 22889 Cusec 56.00 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
23543	614

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
614	0	23169	22889	0	527	30.00



(Hemant Pandey)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 3: 20:45 Hrs on 30.11.2022 to 06:30 Hrs on 01.12.2022.

Unit No. 4: 20:55 Hrs on 30.11.2022 to 06:35 Hrs on 01.12.2022.

Tanuj Aw
01/12/22
JE (EMC)