



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-Dec-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 03-Dec-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	3-Dec-22	0:00:00	3-Dec-22	24:00:00	24:00:00	50.00	1.184	Today (i.e. 04.12.2022), 5 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	3-Dec-22	0:00:00	3-Dec-22	24:00:00	24:00:00	49.00	1.171	
3	3-Dec-22	0:00:00	3-Dec-22	24:00:00	24:00:00	50.00	1.177	
4	3-Dec-22	0:00:00	3-Dec-22	24:00:00	24:00:00	50.00	1.185	
5	3-Dec-22	0:00:00	3-Dec-22	24:00:00	24:00:00	47.00	1.114	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	3-Dec-22	0:00:00	3-Dec-22	0:00:00	0:00:00	0	0.000	Today (i.e. 04.12.2022), 0 SSP-RBPH M/C is running at 9:00 hrs RBPH Unit NO.1 under AOH from 01.12.2022
2	3-Dec-22	15:00:00	3-Dec-22	19:00:00	4:00:00	204	0.810	
3	3-Dec-22	16:00:00	3-Dec-22	19:15:00	3:15:00	204	0.662	
4	3-Dec-22	16:15:00	3-Dec-22	19:30:00	3:15:00	203	0.668	
5	3-Dec-22	16:30:00	3-Dec-22	20:00:00	3:30:00	203	0.720	
6	3-Dec-22	0:00:00	3-Dec-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	5.831	2.860	8.691
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	17.514	5.214	22.728
PREVIOUS DAY ACTUAL RUNNING HOURS	120:00:00	14:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	13:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	13:45:00	

SSP hydrological data : at 08:00 Hrs on 4-Dec-22  
DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.60 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 8416 Cusec 20.59 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 26940 Cusec 65.91 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
23188	614

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
612	0	22634	23009	3931	482	30.00



Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil

(Hemant Pandey)  
Executive Engineer (EMC)  
NCA, INDORE

*Handwritten signature and date:*  
24/12/22  
J.B. (Elect)  
EMC, N.C.A.