



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 05-Dec-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 04-Dec-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Dec-22	0:00:00	4-Dec-22	24:00:00	24:00:00	50.00	1.177	Today (i.e. 05.12.2022), 5 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	4-Dec-22	0:00:00	4-Dec-22	24:00:00	24:00:00	50.00	1.164	
3	4-Dec-22	0:00:00	4-Dec-22	24:00:00	24:00:00	51.00	1.185	
4	4-Dec-22	0:00:00	4-Dec-22	24:00:00	24:00:00	51.00	1.198	
5	4-Dec-22	00:00 19:00	4-Dec-22	11:30 24:00	16:30:00	48.00	0.749	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Dec-22	0:00:00	4-Dec-22	0:00:00	0:00:00	0	0.000	Today (i.e. 05.12.2022), 1 SSP-RBPH M/C is running at 9:00 hrs RBPH Unit NO.1 under AOH from 01.12.2022
2	4-Dec-22	0:00:00	4-Dec-22	0:00:00	0:00:00	0	0.000	
3	4-Dec-22	15:00:00	4-Dec-22	18:45:00	3:45:00	204	0.766	
4	4-Dec-22	15:15:00	4-Dec-22	19:00:00	3:45:00	204	0.770	
5	4-Dec-22	16:15:00	4-Dec-22	19:15:00	3:00:00	203	0.618	
6	4-Dec-22	16:30:00	4-Dec-22	19:30:00	3:00:00	205	0.614	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	5.473	2.768	8.241
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	22.987	7.982	30.969
PREVIOUS DAY ACTUAL RUNNING HOURS	112:30:00	13:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	115:30:00	13:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	13:45:00	

SSP hydrological data : at 08:00 Hrs on 5-Dec-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.45 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 6423 Cusec 15.71 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 24952 Cusec 61.05 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
22634	610

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
620	0	21352	20990	3962	478	30.00



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadodra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 2: 22:10 Hrs on 04.12.2022 to 06:30 Hrs on 05.12.2022.

Unit No. 5: 22:30 Hrs on 04.12.2022 to 06:40 Hrs on 05.12.2022.

Prepared by
J.E. (Elect)
EMC, NCA