



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 06-Dec-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 05-Dec-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	5-Dec-22	0:00:00	5-Dec-22	24:00:00	24:00:00	50.00	1.171	Today (i.e. 06.12.2022), 5 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	5-Dec-22	0:00:00	5-Dec-22	24:00:00	24:00:00	50.00	1.186	
3	5-Dec-22	0:00:00	5-Dec-22	24:00:00	24:00:00	51.00	1.177	
4	5-Dec-22	0:00:00	5-Dec-22	24:00:00	24:00:00	51.00	1.187	
5	5-Dec-22	00:00 6:30	5-Dec-22	2:00 24:00	19:30:00	50.00	0.895	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	5-Dec-22	0:00:00	5-Dec-22	0:00:00	0:00:00	0	0.000	Today (i.e. 06.12.2022), 0 SSP-RBPH M/C is running at 9:00 hrs RBPH Unit NO.1 under AOH from 01.12.2022
2	5-Dec-22	0:00:00	5-Dec-22	0:00:00	0:00:00	0	0.000	
3	5-Dec-22	15:00:00	5-Dec-22	19:00:00	4:00:00	204	0.816	
4	5-Dec-22	7:15:00	5-Dec-22	9:45:00	2:30:00	202	0.514	
5	5-Dec-22	15:30:00	5-Dec-22	19:15:00	3:45:00	203	0.766	
6	5-Dec-22	16:15:00	5-Dec-22	19:45:00	3:30:00	205	0.712	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	5.616	2.808	8.424
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	28.603	10.790	39.393
PREVIOUS DAY ACTUAL RUNNING HOURS	115:30:00	13:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	120:00:00	13:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	120:00:00	14:00:00	

SSP hydrological data : at 08:00 Hrs on 6-Dec-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 134.25 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 2283 Cusec 5.59 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 27151 Cusec 66.43 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
21352	620

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
620	0	23115	23127	4024	473	30.00



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 4: 20:15 Hrs on 05.12.2022 to 06:55 Hrs on 06.12.2022.

Unit No. 3: 20:30 Hrs on 05.12.2022 to 06:50 Hrs on 06.12.2022.

Prepared by
J.E. (Elect)
EMC, NCA