



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 10-Dec-22

ISSUE TIME: 9:30 Hrs

FOR DATE: 09-Dec-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Dec-22	0:00:00	9-Dec-22	2:30:00	2:30:00	50.00	0.125	Today (i.e. 10.12.2022), 3 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	9-Dec-22	0:00:00	9-Dec-22	24:00:00	24:00:00	51.00	1.177	
3	9-Dec-22	0:00:00	9-Dec-22	24:00:00	24:00:00	51.00	1.199	
4	9-Dec-22	6:30:00	9-Dec-22	24:00:00	17:30:00	51.00	0.874	
5	9-Dec-22	0:00:00	9-Dec-22	21:30:00	21:30:00	48.00	0.990	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Dec-22	0:00:00	9-Dec-22	0:00:00	0:00:00	0	0.000	Today (i.e. 10.12.2022), 0 SSP-RBPH M/C is running at 9:00 hrs RBPH Unit No.1 under AOH from 01.12.2022
2	9-Dec-22	15:00:00	9-Dec-22	18:45:00	3:45:00	203	0.752	
3	9-Dec-22	15:15:00	9-Dec-22	19:00:00	3:45:00	203	0.758	
4	9-Dec-22	15:30:00	9-Dec-22	19:15:00	3:45:00	204	0.756	
5	9-Dec-22	0:00:00	9-Dec-22	0:00:00	0:00:00	0	0.000	
6	9-Dec-22	15:45:00	9-Dec-22	19:30:00	3:45:00	203	0.754	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	4.365	3.020	7.385
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	48.784	22.292	71.076
PREVIOUS DAY ACTUAL RUNNING HOURS	89:30:00	15:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	86:15:00	14:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	14:00:00	

SSP hydrological data : at 08:00 Hrs on 10-Dec-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 133.70 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9509 Cusec 23.26 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21723 Cusec 53.15 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
18691	628

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
622	0	16016	17110	4613	458	30.00



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 2: 21:30 Hrs on 09.12.2022 to 06:25 Hrs on 10.12.2022.

Unit No. 6: 21:20 Hrs on 09.12.2022 to 06:30 Hrs on 10.12.2022.

Touseef
10/12/22
JE(EMC)