



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 15-Dec-22
ISSUE TIME: 9:30 Hrs
FOR DATE: 14-Dec-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
	DATE	TIME	DATE	TIME				
1	14-Dec-22	0:00:00	14-Dec-22	24:00:00	24:00:00	50.00	1.186	Today (i.e. 15.12.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	14-Dec-22	0:00:00	14-Dec-22	24:00:00	24:00:00	51.00	1.202	
3	14-Dec-22	0:00:00	14-Dec-22	24:00:00	24:00:00	50.00	1.194	
4	14-Dec-22	0:00:00	14-Dec-22	24:00:00	24:00:00	50.00	1.192	
5	14-Dec-22	0:00 17:30	14-Dec-22	0:30 22:45	5:45:00	49.00	0.274	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
	DATE	TIME	DATE	TIME				
1	14-Dec-22	0:00:00	14-Dec-22	0:00:00	0:00:00	0	0.000	Today (i.e. 15.12.2022), 0 SSP-RBPH M/C is running at 9:00 hrs RBPH Unit No.1 under AOH from 01.12.2022
2	14-Dec-22	0:00:00	14-Dec-22	0:00:00	0:00:00	0	0.000	
3	14-Dec-22	0:00:00	14-Dec-22	0:00:00	0:00:00	0	0.000	
4	14-Dec-22	0:00:00	14-Dec-22	0:00:00	0:00:00	0	0.000	
5	14-Dec-22	0:00:00	14-Dec-22	0:00:00	0:00:00	0	0.000	
6	14-Dec-22	0:00:00	14-Dec-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	5.048	0.000	5.048
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	75.012	27.998	103.010
PREVIOUS DAY ACTUAL RUNNING HOURS	101:45:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 15-Dec-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 132.98 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4684 Cusec 11.46 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 20717 Cusec 50.69 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
20844	615

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
617	0	19967	20717	0	440	26.00



(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil

Rajesh Sharma
15/12/22
JE(EMC)