



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 20-Dec-22

ISSUE TIME: 9:30 Hrs

FOR DATE: 19-Dec-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Dec-22	0:00:00	19-Dec-22	0:00:00	0:00:00	0.00	0.000	Today (i.e. 20.12.2022), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	19-Dec-22	0:00:00	19-Dec-22	24:00:00	24:00:00	50.00	1.197	
3	19-Dec-22	0:00:00	19-Dec-22	24:00:00	24:00:00	51.00	1.196	
4	19-Dec-22	0:00:00	19-Dec-22	24:00:00	24:00:00	50.00	1.188	
5	19-Dec-22	0:00:00	19-Dec-22	24:00:00	24:00:00	48.00	1.118	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	19-Dec-22	0:00:00	19-Dec-22	0:00:00	0:00:00	0	0.000	Today (i.e. 20.12.2022), 0 SSP-RBPH M/C is running at 9:00 hrs RBPH Unit No.1 under AOH from 01.12.2022
2	19-Dec-22	0:00:00	19-Dec-22	0:00:00	0:00:00	0	0.000	
3	19-Dec-22	0:00:00	19-Dec-22	0:00:00	0:00:00	0	0.000	
4	19-Dec-22	0:00:00	19-Dec-22	0:00:00	0:00:00	0	0.000	
5	19-Dec-22	0:00:00	19-Dec-22	0:00:00	0:00:00	0	0.000	
6	19-Dec-22	0:00:00	19-Dec-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	4.699	0.000	4.699
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	100.268	27.998	128.266
PREVIOUS DAY ACTUAL RUNNING HOURS	96:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	91:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 20-Dec-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 132.45 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 7767 Cusec 19.00 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18745 Cusec 45.86 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
20138	621

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
631	0	19191	18745	0	426	26.00



Rajesh Sharma
20/12/22
(Rajesh Sharma)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 3: 21:30 Hrs on 19.12.2022 to 22:50 Hrs on 19.12.2022.

Unit No. 6: 21:40 Hrs on 19.12.2022 to 23:00 Hrs on 19.12.2022.

Tarun Jha
20/12/22
JE (EMC)