



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 27-Dec-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 26-Dec-22

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	26-Dec-22	00:00 06:30 18:30	26-Dec-22	01:30 14:00 23:00	13:30:00	51.00	0.664	Today (i.e. 27.12.2022), 5 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	26-Dec-22	0:00:00	26-Dec-22	24:00:00	24:00:00	50.00	1.193	
3	26-Dec-22	0:00:00	26-Dec-22	24:00:00	24:00:00	50.00	1.196	
4	26-Dec-22	0:00:00	26-Dec-22	24:00:00	24:00:00	52.00	1.213	
5	26-Dec-22	0:00:00	26-Dec-22	24:00:00	24:00:00	47.00	1.103	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	26-Dec-22	0:00:00	26-Dec-22	0:00:00	0:00:00	0	0.000	Today (i.e. 27.12.2022), 0 SSP-RBPH M/C is running at 9:00 hrs RBPH Unit No.1 under AOH extended from 01.12.2022
2	26-Dec-22	0:00:00	26-Dec-22	0:00:00	0:00:00	0	0.000	
3	26-Dec-22	0:00:00	26-Dec-22	0:00:00	0:00:00	0	0.000	
4	26-Dec-22	0:00:00	26-Dec-22	0:00:00	0:00:00	0	0.000	
5	26-Dec-22	0:00:00	26-Dec-22	0:00:00	0:00:00	0	0.000	
6	26-Dec-22	0:00:00	26-Dec-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	5.369	0.000	5.369
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	136.721	27.998	164.719
PREVIOUS DAY ACTUAL RUNNING HOURS	109:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	113:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 27-Dec-22

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 132.25 Mtrs. ✓
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 22437 Cusec 54.89 MCM ✓
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 22018 Cusec 53.87 MCM ✓
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
21824	619

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
621	0	20856	22018	0	420	30.00



(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 2: 22:10 Hrs on 26.12.2022 to 06:20 Hrs on 27.12.2022.

Unit No. 4: 22:20 Hrs on 26.12.2022 to 06:45 Hrs on 27.12.2022.

Prepared by  
Tauseef AH  
JE (EMC)  
27/12/22