



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 30-Dec-22  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 29-Dec-22

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Dec-22	6:30:00	29-Dec-22	24:00:00	17:30:00	50.00	0.862	Today (i.e. 30.12.2022), 5 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	29-Dec-22	0:00:00	29-Dec-22	24:00:00	24:00:00	50.00	1.188	
3	29-Dec-22	0:00:00	29-Dec-22	24:00:00	24:00:00	50.00	1.183	
4	29-Dec-22	0:00:00	29-Dec-22	24:00:00	24:00:00	51.00	1.207	
5	29-Dec-22	0:00:00	29-Dec-22	24:00:00	24:00:00	49.00	1.105	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	29-Dec-22	0:00:00	29-Dec-22	0:00:00	0:00:00	0	0.000	Today (i.e. 30.12.2022), 0 SSP-RBPH M/C is running at 9:00 hrs
2	29-Dec-22	0:00:00	29-Dec-22	0:00:00	0:00:00	0	0.000	
3	29-Dec-22	0:00:00	29-Dec-22	0:00:00	0:00:00	0	0.000	
4	29-Dec-22	0:00:00	29-Dec-22	0:00:00	0:00:00	0	0.000	
5	29-Dec-22	0:00:00	29-Dec-22	0:00:00	0:00:00	0	0.000	
6	29-Dec-22	0:00:00	29-Dec-22	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	5.545	0.000	5.545
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	152.299	27.998	180.297
PREVIOUS DAY ACTUAL RUNNING HOURS	113:30:00	0:00:00	
TODAY's DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 30-Dec-22

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 132.08 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 16336 Cusec 39.97 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 23522 Cusec 57.55 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
20453	620

AVERAGE OUTFLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
621	0	22984	23522	0	416	28.00



नर्मदा नियंत्रण प्राधिकरण

Prepared by -  
Arjun  
(Arjun Sharma)  
JE, EMC, NCA

Arjun  
30/12/22  
(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE  
JE, EMC, NCA

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member (Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE(E&M), SSNNL, Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil