



NARMADA CONTROL AUTHORITY, REGIONAL OFFICE HYDROLOGY DIRECTORATE, INDORE




Daily Status of Narmada River Basin at 08:00 hrs. on 18 February, 2022

S. No	Name of Station	FRL/Danger level Meter	Water Level Metre	Live Storage as on today MCM	Inflow/ # Discharge Cumec	Average Outflows during last 24 hrs.					Remarks
						Spillway Cumec	PH Rel.		HR Rel. Cumec	Total Rel. Cumec	
							RBPH	CHPH			
1	Bargi Reservoir	422.76	419.55	2324	*	-	128.1	-	20.0	148.1	
2	Burmanghat	322.00	308.42	-	94						
3	Tawa Reservoir	355.40	348.33	855	*	-	-	116.9	139.6	139.6	
4	Hoshangabad	293.83	284.63	-	168						
5	ISP Reservoir	262.13	255.05	4344	239	-	354.1	-	70.0	424.1	
6	OSP Reservoir	196.60	194.62	106	417	-	463.2	-	72.3	535.5	
7	Maheshwar Reservoir	162.76	146.30	-	-						
8	SSP Reservoir	138.68	121.31	1455	317	-	0.0	516.9	547.2 [§]	516.9	

Power Generation from Sardar Sarovar Project **3.331 MU**s

Average discharge measured at

(i) Godbole Weir	17.41	Cumec	Garudeshwar Weir	19.95	Cumec	Ex-MP Releases	463.2	Cumec
(ii) Gujarat-Rajasthan Border	38.85	Cumec					40.02	MCM



Note:

- # - The above information on inflow is indicative and on the basis provided by project Authorities. Evaporation in all the reservoirs needs to be included in water balancing.
- Water level, Discharge (at G&D site) & Live Storage are at 08:00 hrs on the day. # - Inflow (into reservoir), Spillway, PH & HR releases are 24 hours average of preceding day.
- § - Water released through CHPH/IBPT is diverted to HR of NMC & Godbole gate for env. use.
- * As the releases/outflows are not matching with that of change in storage, inflow is not reported.

Copy forwarded to

- NCA : Executive Member, Member(Civil/Power/E&R), Chief Engineer, Director (Civil), Director (IA&R), SE (EMC), NCA, Indore.
- GoMP : Vice Chairman, NVDA, Member (Engg), NVDA, Bhopal
- GoG : Director (Civil), SSNNL, Gandhi Nagar, Chief Engineer (D&V), SSNNL, Vadodara, SE (Design), SSNNL, Vadodara
- GoM : Chief Engineer, Tapi Irrigation Development Corporation Ltd. Jalgaon.
- GoR : Chief Engineer, NMC, Sanchore

For **JE(C)**
18/02/22

(R. Parmar)
Assistant Director (HM)