




NARMADA CONTROL AUTHORITY, REGIONAL OFFICE
HYDROLOGY DIRECTORATE, INDORE
Daily Status of Narmada River Basin at 08:00 hrs. on 19 March, 2022



S. No	Name of Station	FRL/Danger level	Water Level	Live Storage as on today	Inflow/ # Discharge	Average Outflows during last 24 hrs.					Remarks
		Meter	Metre	MCM	Cumec	Spillway	PH Rel.		HR Rel.	Total Rel.	
1	Bargi Reservoir	422.76	418.15	1983	12	-	115.7	-	8.0	123.7	
2	Burmanghat	322.00	308.46	-	99						
3	Tawa Reservoir	355.40	347.59	768	7	-	-	-	0.4	0.4	
4	Hoshangabad	293.83	284.63	-	168						
5	ISP Reservoir	262.13	253.14	3338	138	-	340.0	-	70.0	410.0	
6	OSP Reservoir	196.60	194.60	105	334	-	695.3	-	56.4	751.7	
7	Maheshwar Reservoir	162.76	146.50	-	-						
8	SSP Reservoir	138.68	119.41	1134	644	-	0.0	482.8	516.9 ^s	482.8	

Power Generation from Sardar Sarovar Project **2.671 MU**s

Average discharge measured at (i) Godbole Weir **17.47 (11 hrs) Cumec** Garudeshwar Weir **20.60 Cumec** Ex-MP Releases **695.3 Cumec**
(ii) Gujarat-Rajasthan Border **4.25 Cumec** **60.07 MCM**



Note : # - The above information on inflow is indicative and on the basis provided by project Authorities. Evaporation in all the reservoirs needs to be included in water balancing.
Water level, Discharge (at G&D site) & Live Storage are at 08:00 hrs on the day. # - Inflow (into reservoir), Spillway, PH & HR releases are 24 hours average of preceding day.
\$ - Water released through CHPH/IBPT is diverted to HR of NMC & Godbole gate for env. use.

Copy forwarded to

- NCA : Executive Member, Member(Civil/Power/E&R), Chief Engineer, Director (Civil), Director (IA&R), SE (EMC), NCA, Indore.
- GoMP : Vice Chairman, NVDA, Member (Engg), NVDA, Bhopal
- GoG : Director (Civil), SSNNL, Gandhi Nagar, Chief Engineer (D&V), SSNNL, Vadodara, SE (Design), SSNNL, Vadodara
- GoM : Chief Engineer, Tapi Irrigation Development Corporation Ltd. Jalgaon.
- GoR : Chief Engineer, NMC, Sanchore

For

19/03/22

(R. Parmar)
Assistant Director (HM)