



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-Jan-23  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 03-Jan-23

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Jan-23	06:30 17:30	3-Jan-23	09:00 24:00	9:00:00	50.00	0.448	Today (i.e. 04.01.2023), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	3-Jan-23	0:00:00	3-Jan-23	24:00:00	24:00:00	50.00	1.204	
3	3-Jan-23	0:00:00	3-Jan-23	24:00:00	24:00:00	50.00	1.188	
4	3-Jan-23	0:00:00	3-Jan-23	24:00:00	24:00:00	50.00	1.200	
5	3-Jan-23	0:00:00	3-Jan-23	24:00:00	24:00:00	46.00	1.084	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	3-Jan-23	0:00:00	3-Jan-23	0:00:00	0:00:00	0	0.000	Today (i.e. 04.01.2023), 0 SSP-RBPH M/C is running at 9:00 hrs
2	3-Jan-23	0:00:00	3-Jan-23	0:00:00	0:00:00	0	0.000	
3	3-Jan-23	0:00:00	3-Jan-23	0:00:00	0:00:00	0	0.000	
4	3-Jan-23	0:00:00	3-Jan-23	0:00:00	0:00:00	0	0.000	
5	3-Jan-23	0:00:00	3-Jan-23	0:00:00	0:00:00	0	0.000	
6	3-Jan-23	0:00:00	3-Jan-23	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	5.124	0.000	5.124
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	15.446	0.000	15.446
PREVIOUS DAY ACTUAL RUNNING HOURS	105:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	101:30:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 4-Jan-23

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 131.74 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12188 Cusec 29.82 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 22074 Cusec 54.01 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
21262	620

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
617	0	22011	22074	0	425	28.00



(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSNNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, and Raj-2 lines are in service.

2. SCO Mode Detail:-

Nil

*Prepared by  
Tarekesh Ah  
04/01/23  
JE(EMC)*