



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 11-Jan-23  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 10-Jan-23

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Jan-23	23:00:00	10-Jan-23	24:00:00	1:00:00	50.00	0.051	Today (i.e. 11.01.2023), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	10-Jan-23	0:00:00	10-Jan-23	24:00:00	24:00:00	50.00	1.181	
3	10-Jan-23	0:00:00	10-Jan-23	9:30:00	9:30:00	50.00	0.470	
4	10-Jan-23	0:00:00	10-Jan-23	24:00:00	24:00:00	51.00	1.201	
5	10-Jan-23	00:00 07:00	10-Jan-23	01:00 24:00	18:00:00	47.00	0.841	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	10-Jan-23	0:00:00	10-Jan-23	0:00:00	0:00:00	0	0.000	Today (i.e. 11.01.2023), 0 SSP-RBPH M/C is running at 9:00 hrs
2	10-Jan-23	0:00:00	10-Jan-23	0:00:00	0:00:00	0	0.000	
3	10-Jan-23	0:00:00	10-Jan-23	0:00:00	0:00:00	0	0.000	
4	10-Jan-23	0:00:00	10-Jan-23	0:00:00	0:00:00	0	0.000	
5	10-Jan-23	0:00:00	10-Jan-23	0:00:00	0:00:00	0	0.000	
6	10-Jan-23	0:00:00	10-Jan-23	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	3.744	0.000	3.744
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	49.152	0.000	49.152
PREVIOUS DAY ACTUAL RUNNING HOURS	76:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 11-Jan-23

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 131.71 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 28881 Cusec 70.66 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 17208 Cusec 42.10 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
18274	610

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
619	0	17821	17208	0	423	28.00



*(Signature)*  
(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG. CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.  
2. SCO Mode Detail:- Nil

*Prepared by  
Tausif AH  
11/01/2023  
JE(EMC)*