



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 12-Jan-23  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 11-Jan-23

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	11-Jan-23	0:00:00	11-Jan-23	24:00:00	24:00:00	50.00	1.189	Today (i.e. 12.01.2023), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	11-Jan-23	0:00:00	11-Jan-23	24:00:00	24:00:00	50.00	1.186	
3	11-Jan-23	16:30:00	11-Jan-23	24:00:00	7:30:00	50.00	0.374	
4	11-Jan-23	0:00:00	11-Jan-23	24:00:00	24:00:00	51.00	1.206	
5	11-Jan-23	0:00:00	11-Jan-23	24:00:00	24:00:00	47.00	1.103	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	11-Jan-23	0:00:00	11-Jan-23	0:00:00	0:00:00	0	0.000	Today (i.e. 12.01.2023), 0 SSP-RBPH M/C is running at 9:00 hrs
2	11-Jan-23	0:00:00	11-Jan-23	0:00:00	0:00:00	0	0.000	
3	11-Jan-23	0:00:00	11-Jan-23	0:00:00	0:00:00	0	0.000	
4	11-Jan-23	0:00:00	11-Jan-23	0:00:00	0:00:00	0	0.000	
5	11-Jan-23	0:00:00	11-Jan-23	0:00:00	0:00:00	0	0.000	
6	11-Jan-23	0:00:00	11-Jan-23	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	5.058	0.000	5.058
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	54.210	0.000	54.210
PREVIOUS DAY ACTUAL RUNNING HOURS	103:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 12-Jan-23

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 131.72 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 22793 Cusec 55.76 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21433 Cusec 52.44 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
17821	619

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
618	0	21986	21433	0	424	28.00



*(Signature)*  
(Rajesh Sharma) 12/1/23  
Executive Engineer (EMC)  
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.  
1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.  
2. SCO Mode Detail:- Nil

Prepared by  
Archita Kharangar  
JE (E&M)  
EMC, NCA