



नर्मदा नियंत्रण प्राधिकरण  
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 16-Jan-23  
ISSUE TIME: 9:30 Hrs  
FOR DATE: 15-Jan-23

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	15-Jan-23	00:00 19:30	15-Jan-23	12:30 24:00	17:00:00	50.00	0.822	Today (i.e. 16.01.2023), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	15-Jan-23	0:00:00	15-Jan-23	24:00:00	24:00:00	50.00	1.177	
3	15-Jan-23	0:00:00	15-Jan-23	24:00:00	24:00:00	50.00	1.175	
4	15-Jan-23	0:00:00	15-Jan-23	24:00:00	24:00:00	50.00	1.185	
5	15-Jan-23	6:30:00	15-Jan-23	24:00:00	17:30:00	49.00	0.814	

**(RBPB 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	15-Jan-23	7:15:00	15-Jan-23	11:30:00	4:15:00	203	0.852	Today (i.e. 16.01.2023), 4 SSP-RBPB M/cs are running at 9:00 hrs
2	15-Jan-23	6:15 15:30	15-Jan-23	10:45 18:30	7:30:00	204	1.514	
3	15-Jan-23	6:30:00	15-Jan-23	11:00:00	4:30:00	202	0.900	
4	15-Jan-23	8:15 15:45	15-Jan-23	11:45 18:45	6:30:00	203	1.318	
5	15-Jan-23	16:00:00	15-Jan-23	19:00:00	3:00:00	200	0.606	
6	15-Jan-23	16:15:00	15-Jan-23	19:15:00	3:00:00	201	0.602	

	CHPH (5 X 50MW)	RBPB (6X200 MW)	SSP(CHPH+RBPB)
GROSS GENERATION IN(MUs)	5.173	5.792	10.965
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	74.490	5.792	80.282
PREVIOUS DAY ACTUAL RUNNING HOURS	106:30:00	28:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	96:00:00	24:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	25:00:00	

SSP hydrological data : at 08:00 Hrs on 16-Jan-23

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 131.62 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 26850 Cusec 65.69 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 30177 Cusec 73.83 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
22937	617

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPB	Ev. Loss	RBPB TRC
617	0	21745	21658	8519	423	28.00



(Rajesh Sharma)  
Executive Engineer (EMC)  
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE: All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

Unit No. 1: 01:00 hrs on 16.01.2023 to 05:50 hrs on 16.01.2023.

Unit No. 3: 01:10 hrs on 16.01.2023 to 05:55 hrs on 16.01.2023.

*Handwritten signature and date:*  
17/01/23  
J.E. (Elect.)  
EMC, NCA