



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 24-Jan-23
ISSUE TIME: 9:30 Hrs
FOR DATE: 23-Jan-23

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	23-Jan-23	00:00 18:00	23-Jan-23	14:00 24:00	20:00:00	51.00	0.977	Today (i.e. 24.01.2023), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	23-Jan-23	0:00:00	23-Jan-23	24:00:00	24:00:00	50.00	1.175	
3	23-Jan-23	0:00:00	23-Jan-23	24:00:00	24:00:00	51.00	1.182	
4	23-Jan-23	0:00:00	23-Jan-23	24:00:00	24:00:00	51.00	1.207	
5	23-Jan-23	0:00:00	23-Jan-23	24:00:00	24:00:00	49.00	1.158	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	23-Jan-23	0:00:00	23-Jan-23	0:00:00	0:00:00	0	0.000	Today (i.e. 24.01.2023), 3 SSP-RBPH M/cs are running at 9:00 hrs
2	23-Jan-23	7:00:00	23-Jan-23	9:30:00	2:30:00	201	0.506	
3	23-Jan-23	06:50 16:15	23-Jan-23	09:20 19:00	5:15:00	204	1.060	
4	23-Jan-23	0:00:00	23-Jan-23	0:00:00	0:00:00	0	0.000	
5	23-Jan-23	7:15:00	23-Jan-23	10:30:00	3:15:00	201	0.660	
6	23-Jan-23	16:00:00	23-Jan-23	18:45:00	2:45:00	203	0.558	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	5.699	2.784	8.483
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	114.611	43.334	157.945
PREVIOUS DAY ACTUAL RUNNING HOURS	116:00:00	13:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	109:30:00	14:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	12:30:00	

SSP hydrological data : at 08:00 Hrs on 24-Jan-23

DATA RECEIVED FROM FLOOD CELL.

- RESERVOIR LEVEL IN Metres 131.32 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 16159 Cusec 39.53 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 26989 Cusec 66.03 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
22957	618

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
620	0	23740	22754	4235	419	30.00



(Hemant Pandey)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

NIL

Prepared by
Tarek/Ah
7/1/23
JE(EMC)