



नर्मदा नियंत्रण प्राधिकरण
NARMADA CONTROL AUTHORITY

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 25-Jan-23
ISSUE TIME: 9:30 Hrs
FOR DATE: 24-Jan-23

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	24-Jan-23	10:30:00	24-Jan-23	24:00:00	13:30:00	50.00	0.666	Today (i.e. 25.01.2023), 4 No. of SSP-CHPH M/cs are running at 9:00 hrs.
2	24-Jan-23	0:00:00	24-Jan-23	24:00:00	24:00:00	50.00	1.179	
3	24-Jan-23	0:00:00	24-Jan-23	24:00:00	24:00:00	51.00	1.194	
4	24-Jan-23	0:00:00	24-Jan-23	24:00:00	24:00:00	51.00	1.204	
5	24-Jan-23	0:00:00	24-Jan-23	24:00:00	24:00:00	48.00	1.133	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	24-Jan-23	0:00:00	24-Jan-23	0:00:00	0:00:00	0	0.000	Today (i.e. 25.01.2023), 2 SSP-RBPH M/cs are running at 9:00 hrs
2	24-Jan-23	6:45:00	24-Jan-23	9:15:00	2:30:00	200	0.506	
3	24-Jan-23	16:15:00	24-Jan-23	19:15:00	3:00:00	204	0.612	
4	24-Jan-23	7:00:00	24-Jan-23	9:30:00	2:30:00	204	0.510	
5	24-Jan-23	7:15:00	24-Jan-23	10:45:00	3:30:00	201	0.708	
6	24-Jan-23	16:00:00	24-Jan-23	19:00:00	3:00:00	202	0.610	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	5.376	2.946	8.322
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	119.987	46.280	166.267
PREVIOUS DAY ACTUAL RUNNING HOURS	109:30:00	14:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	109:30:00	12:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	96:00:00	12:30:00	

SSP hydrological data : at 08:00 Hrs on 25-Jan-23

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 131.12 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10757 Cusec 26.32 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 29090 Cusec 71.17 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
23740	620

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss	RBPH TRC
617	0	24415	24685	4405	416	30.00



(Signature)
(Hemant Pandey)
Executive Engineer (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVEDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Dhule-2, Raj-1 and Raj-2 lines are in service.

2. SCO Mode Detail:-

NIL