



**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	18-Apr-18	0:00:00	18-Apr-18	0:00:00	0:00:00	0.00	0.000	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m).  SSP-CHPH Unit no. 4 is under AOH from dt. 10.04.2018
2	18-Apr-18	0:00:00	18-Apr-18	0:00:00	0:00:00	0.00	0.000	
3	18-Apr-18	0:00:00	18-Apr-18	0:00:00	0:00:00	0.00	0.000	
4	18-Apr-18	0:00:00	18-Apr-18	0:00:00	0:00:00	0.00	0.000	
5	18-Apr-18	0:00:00	18-Apr-18	0:00:00	0:00:00	0.00	0.000	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	18-Apr-18	0:00:00	18-Apr-18	0:00:00	0:00:00	0	0.000	SSP-RBPH units will not be scheduled as Dam Level is below MDDL(110.64m).  SSP-RBPH Unit no. 4 is under AOH from dt. 04.04.2018
2	18-Apr-18	0:00:00	18-Apr-18	0:00:00	0:00:00	0	0.000	
3	18-Apr-18	0:00:00	18-Apr-18	0:00:00	0:00:00	0	0.000	
4	18-Apr-18	0:00:00	18-Apr-18	0:00:00	0:00:00	0	0.000	
5	18-Apr-18	0:00:00	18-Apr-18	0:00:00	0:00:00	0	0.000	
6	18-Apr-18	0:00:00	18-Apr-18	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.000	0.000	0.000
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	0.000	0.000	0.000
PREVIOUS DAY ACTUAL RUNNING HOURS	0:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	0:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	0:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 19-Apr-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 104.71 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 3963 Cusec 10 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 3233 Cusec 8 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2472	642

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
613	0	2472	0	0	3233



for Archita Kawango  
AEE (EMC)  
NCA, INDORE  
19.04.18

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG CE(E&M),SSNNL,Vadodra

NOTE :I) All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

II) SSP-RBPH SCO Mode Operation:- No M/c was in SCO Mode due to low Dam level.

III) IBPT operated for maintaining environmental flow into the downstream.