



(CHPH 5X50 MW)								
Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Apr-18	0:00:00	1-Apr-18	0:00:00	0:00:00	0.00	0.000	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m), SSP-CHPH Unit no. 1 is under AOH from dt. 20/03,2018
2	1-Apr-18	0:00:00	1-Apr-18	0:00:00	0:00:00	0.00	0.000	
3	1-Apr-18	0:00:00	1-Apr-18	0:00:00	0:00:00	0.00	0.000	
4	1-Apr-18	0:00:00	1-Apr-18	0:00:00	0:00:00	0.00	0.000	
5	1-Apr-18	0:00:00	1-Apr-18	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)								
Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	1-Apr-18	0:00:00	1-Apr-18	0:00:00	0:00:00	0	0.000	SSP-RBPH units will not be scheduled as Dam Level is below MDDL(110.64m).
2	1-Apr-18	0:00:00	1-Apr-18	0:00:00	0:00:00	0	0.000	
3	1-Apr-18	0:00:00	1-Apr-18	0:00:00	0:00:00	0	0.000	
4	1-Apr-18	0:00:00	1-Apr-18	0:00:00	0:00:00	0	0.000	
5	1-Apr-18	0:00:00	1-Apr-18	0:00:00	0:00:00	0	0.000	
6	1-Apr-18	0:00:00	1-Apr-18	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.000	0.000	0.000
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	0.000	0.000	0.000
PREVIOUS DAY ACTUAL RUNNING HOURS	0:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	0:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	0:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 2-Apr-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 105.38 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 1805 Cusec 4 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 2605 Cusec 6 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2850	649

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
613	0	2299	0	0	2605



(Signature)

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP, Member(Power), NVDA, Bhopal
- GoMah, CE, WRD, Mumbai
- GoG, CE(E&M), SSNNI, Vadodra

NOTE : I) All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
II) SSP-RBPH SCO Mode Operation:- No M/c was in SCO Mode due to low Dam level.
III) IBPT operated for maintaining environmental flow into the downstream.

AEE (EMC)
NCA, INDORE