



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-Apr-18	0:00:00	22-Apr-18	0:00:00	0:00:00	0.00	0.000	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m). SSP-CHPH Unit no. 4 is under AOH from dt. 10.04.2018
2	22-Apr-18	0:00:00	22-Apr-18	0:00:00	0:00:00	0.00	0.000	
3	22-Apr-18	0:00:00	22-Apr-18	0:00:00	0:00:00	0.00	0.000	
4	22-Apr-18	0:00:00	22-Apr-18	0:00:00	0:00:00	0.00	0.000	
5	22-Apr-18	0:00:00	22-Apr-18	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-Apr-18	0:00:00	22-Apr-18	0:00:00	0:00:00	0	0.000	SSP-RBPH units will not be scheduled as Dam Level is below MDDL(110.64m). SSP-RBPH Unit no. 4 is under AOH from dt. 04.04.2018
2	22-Apr-18	0:00:00	22-Apr-18	0:00:00	0:00:00	0	0.000	
3	22-Apr-18	0:00:00	22-Apr-18	0:00:00	0:00:00	0	0.000	
4	22-Apr-18	0:00:00	22-Apr-18	0:00:00	0:00:00	0	0.000	
5	22-Apr-18	0:00:00	22-Apr-18	0:00:00	0:00:00	0	0.000	
6	22-Apr-18	0:00:00	22-Apr-18	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	0.000	0.000	0.000
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	0.000	0.000	0.000
PREVIOUS DAY ACTUAL RUNNING HOURS	0:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	0:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	0:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 23-Apr-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 104.63 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 1892 Cusec 5 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 3086 Cusec 8 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
NA	NA

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
618	0	2454	0	0	3086



for Ascheta Kawing
23.04.18
AEE (EMC)
NCA, INDORE

Copy to:

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP. Member(Power), NVDA, Bhopal
- GoMah. CE, WRD, Mumbai
- GoG CE(E&M), SSNNL, Vadoadra

NOTE :I) All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

II) SSP-RBPH SCO Mode Operation:- No M/c was in SCO Mode due to low Dam level.

III) IBPT operated for maintaining environmental flow into the downstream.