



(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Apr-18	0:00:00	4-Apr-18	0:00:00	0:00:00	0.00	0.000	SSP-CHPH Units will not be scheduled as Dam Level is below MDDL(110.64m). SSP-CHPH Unit no. 1 is under AOH from dt. 20.03.2018
2	4-Apr-18	0:00:00	4-Apr-18	0:00:00	0:00:00	0.00	0.000	
3	4-Apr-18	0:00:00	4-Apr-18	0:00:00	0:00:00	0.00	0.000	
4	4-Apr-18	0:00:00	4-Apr-18	0:00:00	0:00:00	0.00	0.000	
5	4-Apr-18	0:00:00	4-Apr-18	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	4-Apr-18	0:00:00	4-Apr-18	0:00:00	0:00:00	0	0.000	SSP-RBPH units will not be scheduled as Dam Level is below MDDL(110.64m). SSP-RBPH Unit no. 4 is under AOH from dt. 04.04.2018
2	4-Apr-18	0:00:00	4-Apr-18	0:00:00	0:00:00	0	0.000	
3	4-Apr-18	0:00:00	4-Apr-18	0:00:00	0:00:00	0	0.000	
4	4-Apr-18	0:00:00	4-Apr-18	0:00:00	0:00:00	0	0.000	
5	4-Apr-18	0:00:00	4-Apr-18	0:00:00	0:00:00	0	0.000	
6	4-Apr-18	0:00:00	4-Apr-18	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.000	0.000	0.000
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	0.000	0.000	0.000
PREVIOUS DAY ACTUAL RUNNING HOURS	0:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	0:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	0:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 5-Apr-18

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres **105.35 Mtrs.**
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). **3717 Cusec** **9 MCM**
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). **2981 Cusec** **7 MCM**
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2380	625

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	IBPT
635	0	2346	0	0	2981



[Signature]
4/4/18
AEE (EMC)
NCA, INDORE

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.
- GoMP, Member(Power), NVDA, Bhopal
- GoMah, CE, WRD, Mumbai
- GoG, CE(E&M), SSNNL, Vadodra

NOTE : I) All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.
II) SSP-RBPH SCO Mode Operation: - No M/c was in SCO Mode due to low Dam level.
III) IBPT operated for maintaning environmental flow into the downstream.