



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 13-Apr-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 12-Apr-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Apr-19	0:00:00	12-Apr-19	0:00:00	0:00:00	0.00	0.000	Today(i.e. 13.04.2019), 1 CHPH M/c is running at 10:00 hrs.
2	12-Apr-19	0:00:00	12-Apr-19	0:00:00	0:00:00	0.00	0.000	
3	12-Apr-19	0:00:00	12-Apr-19	0:00:00	0:00:00	0.00	0.000	
4	12-Apr-19	0:00:00	12-Apr-19	24:00:00	24:00:00	33.00	0.783	
5	12-Apr-19	17:00:00	12-Apr-19	24:00:00	7:00:00	31.00	0.221	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	12-Apr-19	0:00:00	12-Apr-19	0:00:00	0:00:00	0	0.000	Today(i.e. 13.04.2019), no SSP-RBPH M/c is scheduled. Unit No. 6 is under AOH from 06.04.2019 at 9:00 Hrs..
2	12-Apr-19	0:00:00	12-Apr-19	0:00:00	0:00:00	0	0.000	
3	12-Apr-19	0:00:00	12-Apr-19	0:00:00	0:00:00	0	0.000	
4	12-Apr-19	0:00:00	12-Apr-19	0:00:00	0:00:00	0	0.000	
5	12-Apr-19	0:00:00	12-Apr-19	0:00:00	0:00:00	0	0.000	
6	12-Apr-19	0:00:00	12-Apr-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	1.004	0.000	1.004
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	11.156	0.000	11.156
PREVIOUS DAY ACTUAL RUNNING HOURS	31:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 13-Apr-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.21 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5756 Cusec 14 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 6383 Cusec 16 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
5352	640

AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
640	0	5386	6383	0	541



for
13/04/19

AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG CE(E&M), SSSNL, Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Raj-1 and Dhule-2 lines are in service.

2. SCO Mode Running Detail: