



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 18-Apr-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 17-Apr-19

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|----------|-----------|----------|-------------|----------------|-------------------|----------------------------------------------------------------------------------------------------------------------|
| 1 | 17-Apr-19 | 0:00:00 | 17-Apr-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | Today(i.e. 18.04.2019), 2 CHPH M/c is running at 10:00 hrs. Unit No. 1 is under AOH from 15.04.2019 at 9:00 Hrs.. |
| 2 | 17-Apr-19 | 0:00:00 | 17-Apr-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 3 | 17-Apr-19 | 10:20:00 | 17-Apr-19 | 24:00:00 | 13:40:00 | 31.00 | 0.413 | |
| 4 | 17-Apr-19 | 0:00:00 | 17-Apr-19 | 10:30:00 | 10:30:00 | 32.00 | 0.323 | |
| 5 | 17-Apr-19 | 0:00:00 | 17-Apr-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUS | REMARKS |
|----------|-----------|---------|-----------|---------|-------------|----------------|-------------------|----------------------------------------------------------------------------------------------------------------|
| 1 | 17-Apr-19 | 0:00:00 | 17-Apr-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | Today(i.e. 18.04.2019), no SSP-RBPH M/c is scheduled. Unit No. 6 is under AOH from 06.04.2019 at 9:00 Hrs.. |
| 2 | 17-Apr-19 | 0:00:00 | 17-Apr-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 3 | 17-Apr-19 | 0:00:00 | 17-Apr-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 4 | 17-Apr-19 | 0:00:00 | 17-Apr-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 5 | 17-Apr-19 | 0:00:00 | 17-Apr-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 17-Apr-19 | 0:00:00 | 17-Apr-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|------------------------------------------|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUS) | 0.736 | 0.000 | 0.736 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUS) | 15.614 | 0.000 | 15.614 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 24:10:00 | 0:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 24:00:00 | 0:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 24:00:00 | 0:00:00 | |

SSP hydrological data : at 08:00 Hrs on 18-Apr-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.20 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 4847 Cusec 12 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 5351 Cusec 13 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|------|---------|
| 4847 | 629 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|------|------|------|----------|
| 615 | 0 | 5530 | 5351 | 0 | 540 |



for Shun...
18-4-19
J.B. E.M.C. NCA

A/E (EMC)
NCA, INDORE

Copy to:

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Raj-1, Raj-2 and Dhule-2 lines are in service.

Unit No.4: 20:15 hrs on 17.04.2019 to 06:15 hrs on 18.04.2019

Unit No.2: 20:20 hrs on 17.04.2019 to 06:10 hrs on 18.04.2019