



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 29-Apr-19  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 28-Apr-19

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	28-Apr-19	0:00:00	28-Apr-19	0:00:00	0:00:00	0.00	0.000	
2	28-Apr-19	0:00:00	28-Apr-19	0:00:00	0:00:00	0.00	0.000	
3	28-Apr-19	0:00:00	28-Apr-19	0:00:00	0:00:00	0.00	0.000	
4	28-Apr-19	0:00:00	28-Apr-19	0:00:00	0:00:00	0.00	0.000	
5	28-Apr-19	0:00:00	28-Apr-19	24:00:00	24:00:00	33.00	0.769	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	28-Apr-19	0:00:00	28-Apr-19	0:00:00	0:00:00	0	0.000	Today(i.e. 29.04.2019), no SSP-RBPH M/c is scheduled.
2	28-Apr-19	0:00:00	28-Apr-19	0:00:00	0:00:00	0	0.000	
3	28-Apr-19	0:00:00	28-Apr-19	0:00:00	0:00:00	0	0.000	
4	28-Apr-19	0:00:00	28-Apr-19	0:00:00	0:00:00	0	0.000	
5	28-Apr-19	0:00:00	28-Apr-19	0:00:00	0:00:00	0	0.000	
6	28-Apr-19	0:00:00	28-Apr-19	0:00:00	0:00:00	0	0.000	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.769	0.000	0.769
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	25.147	0.000	25.147
PREVIOUS DAY ACTUAL RUNNING HOURS	24:00:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	0:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	0:00:00	

SSP hydrological data : at 08:00 Hrs on 29-Apr-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.50 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 3299 Cusec 20 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 4829 Cusec 12 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4019	641

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
642	0	4249	4829	0	545

Copy to :

- NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
- GoMP. Member(Power),NVDA,Bhopal
- GoMah. CE,WRD, Mumbai
- GoG. CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Raj-1, Raj-2 and Dhule-2 lines are in service.

2. SCO MODE DETAILS:

Unit No.5: 20:25 hrs on 28.04.2019 to 7:25 hrs on 29.04.2019



AEE (EMC)  
NCA, INDORE