



DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 04-Apr-19
ISSUE TIME: 10:00 Hrs
FOR DATE: 03-Apr-19

(CHPH 5X50 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|---------|----------|----------|-------------|----------------|-------------------|--|
| 1 | 3-Apr-19 | 0:00:00 | 3-Apr-19 | 24:00:00 | 24:00:00 | 33.00 | 0.772 | Today(i.e. 03.04.2019), 1 CHPH M/c is running at 10:00 hrs. Unit No. 3 is under AOH from 27.03.2019 at 9:00 Hrs.. |
| 2 | 3-Apr-19 | 0:00:00 | 3-Apr-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 3 | 3-Apr-19 | 0:00:00 | 3-Apr-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 4 | 3-Apr-19 | 0:00:00 | 3-Apr-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |
| 5 | 3-Apr-19 | 0:00:00 | 3-Apr-19 | 0:00:00 | 0:00:00 | 0.00 | 0.000 | |

(RBPH 6X200 MW)

| Unit No. | START | | STOP | | RUNNING HRS | Max. LOAD (MW) | GENERATION IN MUs | REMARKS |
|----------|----------|---------|----------|---------|-------------|----------------|-------------------|---|
| 1 | 3-Apr-19 | 0:00:00 | 3-Apr-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | Today(i.e. 03.04.2019), no SSP-RBPH M/c is scheduled. |
| 2 | 3-Apr-19 | 0:00:00 | 3-Apr-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 3 | 3-Apr-19 | 0:00:00 | 3-Apr-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 4 | 3-Apr-19 | 0:00:00 | 3-Apr-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 5 | 3-Apr-19 | 0:00:00 | 3-Apr-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |
| 6 | 3-Apr-19 | 0:00:00 | 3-Apr-19 | 0:00:00 | 0:00:00 | 0 | 0.000 | |

| | CHPH (5 X 50MW) | RBPH (6X200 MW) | SSP(CHPH+RBPH) |
|--|-----------------|-----------------|----------------|
| GROSS GENERATION IN(MUs) | 0.772 | 0.000 | 0.772 |
| CUMMULATIVE GROSS GEN. FOR MONTH (MUs) | 2.216 | 0.000 | 2.216 |
| PREVIOUS DAY ACTUAL RUNNING HOURS | 24:00:00 | 0:00:00 | |
| TODAY'S DC (Schedule) Planned (in Hours) | 24:00:00 | 0:00:00 | |
| DAY AHEAD (TOMMORROW) DC (in Hours) | 24:00:00 | 0:00:00 | |

SSP hydrological data : at 08:00 Hrs on 4-Apr-19

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 119.36 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 13067 Cusec 32 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 4948 Cusec 12 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

| HR | GODBOLE |
|------|---------|
| 4564 | 653 |

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

| GODBOLE | OVER FLOW | HR | CHPH | RBPH | Ev. Loss |
|---------|-----------|------|------|------|----------|
| 542 | 0 | 4667 | 4948 | 0 | 542 |



For J.E. NCA.
4/4/19

AEE (EMC)
NCA, INDORE

Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor,Raj-1,Raj-2, and Dhule-2 lines are in service.

2. SSP SCO Running Details:

Unit No.3: 20:20 Hrs on date 03.04.2019 to 09:15Hrs on date 04.04.2019.

Unit No.4: 20:25 Hrs on date 03.04.2019 to 07:15 Hrs on date 04.04.2019.