

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 1-Apr-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 31-Mar-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	31-Mar-20	0:00:00	31-Mar-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 01.04.2020), 2 SSP-CHPH M/cs are running at 10:00 hrs.
2	31-Mar-20	0:00:00	31-Mar-20	0:00:00	0:00:00	0.00	0.000	
3	31-Mar-20	17:30:00	31-Mar-20	24:00:00	6:30:00	40.00	0.252	
4	31-Mar-20	0:00:00	31-Mar-20	24:00:00	24:00:00	40.00	0.944	
5	31-Mar-20	0:00:00	31-Mar-20	24:00:00	24:00:00	40.00	0.930	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	31-Mar-20	0:00:00	31-Mar-20	9:30:00	0:00:00	0	0.000	Today(i.e. 01.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	31-Mar-20	0:00:00	31-Mar-20	0:00:00	0:00:00	0	0.000	
3	31-Mar-20	0:00:00	31-Mar-20	0:00:00	0:00:00	0	0.000	
4	31-Mar-20	0:00:00	31-Mar-20	0:00:00	0:00:00	0	0.000	SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
5	31-Mar-20	0:00:00	31-Mar-20	0:00:00	0:00:00	0	0.000	
6	31-Mar-20	0:00:00	31-Mar-20	0:00:00	0:00:00	0	0.000	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		2.126	0.000	2.126
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		88.191	134.440	222.631
PREVIOUS DAY ACTUAL RUNNING HOURS		54:30:00	0:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		72:00:00	15:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		72:00:00	13:45:00	

SSP hydrological data : at 08:00 Hrs on 1-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 122.05 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 18246 Cusec 45 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14742 Cusec 36 MCM
- GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
10863	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
494	0	11500	12558	2184	542



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.2:15:15 hrs on 31.03.2020 to 5:05 hrs on 01.04.2020.

Unit No.3:14:50 hrs on 31.03.2020 to 5:15 hrs on 01.04.2020.

