

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 10-Apr-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 9-Apr-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

Date: 10-Apr-20

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Apr-20	0:00:00	9-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 10.04.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	9-Apr-20	0:00:00	9-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	9-Apr-20	0:00:00	9-Apr-20	24:00:00	24:00:00	39.00	0.905	
4	9-Apr-20	0:00:00	9-Apr-20	24:00:00	24:00:00	39.00	0.904	
5	9-Apr-20	0:00:00	9-Apr-20	10:00:00	17:00:00	39.00	0.652	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	9-Apr-20	4:30:00	9-Apr-20	8:45:00	4:15:00	183	0.774	Today(i.e. 10.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	9-Apr-20	4:45:00	9-Apr-20	9:15:00	7:30:00	184	1.376	
3	9-Apr-20	5:30:00	9-Apr-20	9:30:00	7:45:00	186	1.426	SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
4	9-Apr-20	16:15:00	9-Apr-20	20:00:00	4:00:00	184	0.740	
5	9-Apr-20	5:45:00	9-Apr-20	9:45:00	0:00:00	0	0.000	
6	9-Apr-20	0:00:00	9-Apr-20	0:00:00	0:00:00	0	0.000	
6	9-Apr-20	5:00:00	9-Apr-20	12:15:00	11:30:00	185	2.120	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		2.461	6.436	8.897
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		22.365	27.708	50.073
PREVIOUS DAY ACTUAL RUNNING HOURS		65:00:00	35:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		72:00:00	11:30:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		72:00:00	11:30:00	

SSP hydrological data : at 08:00 Hrs on 10-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.60 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 21790 Cusec **53 MCM**
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21930 Cusec **54 MCM**
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14153	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	13951	14227	7703	600



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.1:18:20 hrs on 09.04.2020 to 05:35 hrs on 10.04.2020.