



DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 12-Apr-20

ISSUE TIME: 10:00 Hrs

FOR DATE: 11-Apr-20

Daily Plant Report  
(00:00 Hrs to 24:00 Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	11-Apr-20	0:00:00	11-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 12.04.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	11-Apr-20	0:00:00	11-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	11-Apr-20	0:00:00	11-Apr-20	24:00:00	24:00:00	40.00	0.913	
4	11-Apr-20	0:00:00	11-Apr-20	24:00:00	24:00:00	39.00	0.915	
5	11-Apr-20	0:00:17:00	11-Apr-20	10:00:24:00	17:00:00	39.00	0.642	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	11-Apr-20	0:00:00	11-Apr-20	0:00:00	0:00:00	0	0.000	Today(i.e. 12.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	11-Apr-20	0:00:00	11-Apr-20	0:00:00	0:00:00	0	0.000	
3	11-Apr-20	5:45:00	11-Apr-20	8:30:00	2:45:00	184	0.502	SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
4	11-Apr-20	6:15:00	11-Apr-20	9:00:00	2:45:00	183	0.512	
5	11-Apr-20	0:00:00	11-Apr-20	0:00:00	0:00:00	0	0.000	
6	11-Apr-20	6:00:16:00	11-Apr-20	08:45:19:15	6:00:00	185	1.104	

GROSS GENERATION IN(MUS)		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
		2.470	2.118	4.588
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		27.307	31.960	59.267
PREVIOUS DAY ACTUAL RUNNING HOURS		65:00:00	11:30:00	
TODAY'S DC (Schedule) Planned (in Hours)		72:00:00	13:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		72:00:00	13:45:00	

SSP hydrological data : at 08:00 Hrs on 12-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.57 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 17649 Cusec 43 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 17790 Cusec 44 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
13924	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	14443	14274	3516	599



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.1:19:00 hrs on 10.04.2020 to 05:10 hrs on 11.04.2020.

Unit No.2:19:10 hrs on 10.04.2020 to 05:15 hrs on 11.04.2020

AEE (EMC)  
NCA, INDORE