

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 13-Apr-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 12-Apr-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	12-Apr-20	0:00:00	12-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 13.04.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	12-Apr-20	0:00:00	12-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	12-Apr-20	0:00:00	12-Apr-20	24:00:00	24:00:00	40.00	0.902	
4	12-Apr-20	0:00:00	12-Apr-20	24:00:00	24:00:00	39.00	0.930	
5	12-Apr-20	0:00:00	12-Apr-20	24:00:00	24:00:00	39.00	0.907	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	12-Apr-20	0:00:00	12-Apr-20	0:00:00	0:00:00	0	0.000	Today(i.e. 13.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	12-Apr-20	0:00:00	12-Apr-20	0:00:00	0:00:00	0	0.000	
3	12-Apr-20	6:00:00	12-Apr-20	8:45:00	2:45:00	183	0.500	SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
4	12-Apr-20	5:45:00	12-Apr-20	9:00:00	3:15:00	184	0.598	
5	12-Apr-20	0:00:00	12-Apr-20	0:00:00	0:00:00	0	0.000	
6	12-Apr-20	5:30 16:00	12-Apr-20	9:15 20:00	7:45:00	184	1.426	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.739	2.524	5.263
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	30.046	34.484	64.530
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	13:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	13:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	20:00:00	

SSP hydrological data : at 08:00 Hrs on 13-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.53 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 17820 Cusec 44 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 20184 Cusec 49 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
14443	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	15496	15744	4440	599



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRDC respectively. The details:

Unit No.1:20:15 hrs on 12.04.2020 to 04:45 hrs on 13.04.2020.

Unit No.2:20:05 hrs on 12.04.2020 to 04:50 hrs on 13.04.2020