

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 15-Apr-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 14-Apr-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	14-Apr-20	0:00:00	14-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 15.04.2020), 3 SSP-CHPH M/cs are running at 10:00 hrs.
2	14-Apr-20	0:00:00	14-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	14-Apr-20	0:00:00	14-Apr-20	24:00:00	24:00:00	39.00	0.903	
4	14-Apr-20	0:00:00	14-Apr-20	24:00:00	24:00:00	39.00	0.924	
5	14-Apr-20	0:00:00	14-Apr-20	24:00:00	24:00:00	39.00	0.884	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	14-Apr-20	6:30 16:30	14-Apr-20	9:00 19:00	5:00:00	185	0.908	Today(i.e. 15.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	14-Apr-20	6:15:00	14-Apr-20	8:45:00	2:30:00	182	0.462	
3	14-Apr-20	6:00:00	14-Apr-20	8:30:00	2:30:00	185	0.456	SSP RBPH Unit no. 5 is under AOH from 06.03.2020.
4	14-Apr-20	16:15:00	14-Apr-20	19:15:00	3:00:00	183	0.554	
5	14-Apr-20	0:00:00	14-Apr-20	0:00:00	0:00:00	0	0.000	
6	14-Apr-20	5:45 16:00	14-Apr-20	9:15 19:30	7:00:00	185	1.286	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)	2.711	3.666	6.377
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	35.481	40.702	76.183
PREVIOUS DAY ACTUAL RUNNING HOURS	72:00:00	20:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	24:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	24:45:00	

SSP hydrological data : at 08:00 Hrs on 15-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.28 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 15399 Cusec 38 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 23693 Cusec 58 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
16286	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	16204	15795	7898	593



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
GoMP. Member(Power),NVDA,Bhopal
GoMah. CE,WRD, Mumbai
GoG CE(E&M),SSNNL,Vadodra

AEE (EMC)
NCA, INDORE

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.3: 19:55 hrs on 14.04.2020 to 04:20 hrs on 15.04.2020