

**DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES**  
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 16-Apr-20  
ISSUE TIME: 10:00 Hrs  
FOR DATE: 15-Apr-20

Daily Plant Report  
(00:00 Hrs to 24:00Hrs.)

**(CHPH 5X50 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	15-Apr-20	0:00:00	15-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 16.04.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
2	15-Apr-20	0:00:00	15-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	15-Apr-20	0:00:00	15-Apr-20	24:00:00	24:00:00	39.00	0.905	
4	15-Apr-20	0:00:00	15-Apr-20	24:00:00	24:00:00	40.00	0.926	
5	15-Apr-20	0:00:00	15-Apr-20	17:00:00	17:00:00	39.00	0.642	

**(RBPH 6X200 MW)**

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	15-Apr-20	5:15:00	15-Apr-20	9:45:00	4:30:00	186	0.828	Today(i.e. 16.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	15-Apr-20	5:00:00	15-Apr-20	9:30:00	4:30:00	184	0.824	
3	15-Apr-20	5:30:00	15-Apr-20	9:15:00	3:45:00	184	0.692	SSP RBPH Unit no. 5 will not be available due to penstock gate problem.
4	15-Apr-20	4:45:00	15-Apr-20	8:45:00	4:00:00	186	0.742	
5	15-Apr-20	0:00:00	15-Apr-20	0:00:00	0:00:00	0	0.000	
6	15-Apr-20	4:30 20:30	15-Apr-20	9:00 24:00	8:00:00	186	1.458	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	2.473	4.544	7.017
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)	37.954	45.246	83.200
PREVIOUS DAY ACTUAL RUNNING HOURS	65:00:00	24:45:00	
TODAY'S DC (Schedule) Planned (in Hours)	72:00:00	24:45:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	72:00:00	24:00:00	

SSP hydrological data : at 08:00 Hrs on 16-Apr-20

**DATA RECEIVED FROM FLOOD CELL**

- RESERVOIR LEVEL IN Metres 121.15 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 9218 Cusec 23 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 18255 Cusec 45 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
16204	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	10193	11196	7059	0



Copy to :

AEE (EMC)  
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.1: 17:55 hrs on 15.04.2020 to 04:25 hrs on 16.04.2020

Unit No.2: 18:05 hrs on 15.04.2020 to 04:20 hrs on 16.04.2020