

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
 (ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 18-Apr-20
 ISSUE TIME: 10:00 Hrs
 FOR DATE: 17-Apr-20

Daily Plant Report
 (00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	17-Apr-20	0:00:00	17-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 18.04.2020), 1 SSP-CHPH M/cs are running at 10:00 hrs.
2	17-Apr-20	0:00:00	17-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	17-Apr-20	0:00:00	17-Apr-20	2:00:00	9:00:00	40.00	0.337	
4	17-Apr-20	0:00:00	17-Apr-20	24:00:00	24:00:00	39.00	0.918	
5	17-Apr-20	0:00:00	17-Apr-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	17-Apr-20	5:00:00	17-Apr-20	8:15:00	3:15:00	185	0.596	Today(i.e. 18.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	17-Apr-20	4:45:00	17-Apr-20	8:30:00	3:45:00	186	0.692	
3	17-Apr-20	4:30:00	17-Apr-20	8:45:00	4:15:00	185	0.764	SSP RBPH Unit no. 5 will not be available due to penstock gate problem.
4	17-Apr-20	5:20:00	17-Apr-20	9:05:00	3:45:00	187	0.688	
5	17-Apr-20	0:00:00	17-Apr-20	0:00:00	0:00:00	0	0.000	
6	17-Apr-20	4:15:00	17-Apr-20	9:15:00	9:00:00	187	1.662	

GROSS GENERATION IN(MUs)		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
		1.255	4.402	5.657
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		40.522	54.202	94.724
PREVIOUS DAY ACTUAL RUNNING HOURS		33:00:00	24:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		72:00:00	24:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		72:00:00	12:00:00	

SSP hydrological data : at 08:00 Hrs on 18-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.97 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10287 Cusec 25 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 13407 Cusec 33 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
6802	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	6954	7089	6318	583



Copy to :

AEE (EMC)
 NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condensor mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.1: 13:50 hrs on 17.04.2020 to 04:30 hrs on 18.04.2020

Unit No.2: 19:40 hrs on 17.04.2020 to 04:35 hrs on 18.04.2020