

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 21-Apr-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 20-Apr-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	20-Apr-20	0:00:00	20-Apr-20	0:00:00	0:00:00	0.00	0.000	Today (i.e. 21.04.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
2	20-Apr-20	0:00:00	20-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	20-Apr-20	17:00:00	20-Apr-20	24:00:00	7:00:00	37.00	0.259	
4	20-Apr-20	0:00:00	20-Apr-20	11:00:00	11:00:00	38.00	0.415	
5	20-Apr-20	0:00:00	20-Apr-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	20-Apr-20	0:00:00	20-Apr-20	0:00:00	0:00:00	0	0.000	Today (i.e. 21.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs. SSP RBPH Unit no. 5 will not be available due to penstock gate problem.
2	20-Apr-20	6:00:00	20-Apr-20	8:45:00	2:45:00	184	0.512	
3	20-Apr-20	5:45:00	20-Apr-20	8:30:00	2:45:00	185	0.512	
4	20-Apr-20	5:30:00	20-Apr-20	8:15:00	2:45:00	184	0.510	
5	20-Apr-20	0:00:00	20-Apr-20	0:00:00	0:00:00	0	0.000	
6	20-Apr-20	5:15:00	20-Apr-20	8:00:00	2:45:00	185	0.510	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.674	2.044	2.718
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	43.068	62.942	106.010
PREVIOUS DAY ACTUAL RUNNING HOURS	18:00:00	11:00:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	11:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	11:00:00	

SSP hydrological data : at 08:00 Hrs on 21-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.24 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 17236 Cusec 42 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 7022 Cusec 17 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
4138	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	3379	3932	3090	588



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRDC respectively. The details:

Unit No.3: 20:30 hrs on 20.04.2020 to 04:55 hrs on 21.04.2020

Unit No.6: 20:15 hrs on 20.04.2020 to 04:50 hrs on 21.04.2020