

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 23-Apr-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 22-Apr-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-Apr-20	0:00:00	22-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 23.04.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
2	22-Apr-20	0:00:00	22-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	22-Apr-20	0:00:17:00	22-Apr-20	7:00:24:00	14:00:00	37.00	0.523	
4	22-Apr-20	0:00:00	22-Apr-20	0:00:00	0:00:00	0.00	0.000	
5	22-Apr-20	0:00:00	22-Apr-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	22-Apr-20	4:45:15:45	22-Apr-20	7:55:24:00	11:25:00	183	2.072	Today(i.e. 23.04.2020), 4 SSP-RBPH M/cs are running at 10:00 hrs. SSP RBPH Unit no. 5 will not be available due to penstock gate problem.
2	22-Apr-20	5:00:16:00	22-Apr-20	8:15:24:00	11:15:00	184	2.052	
3	22-Apr-20	5:15:16:15	22-Apr-20	8:30:24:00	11:00:00	184	2.002	
4	22-Apr-20	5:30:5:15	22-Apr-20	8:45:24:00	12:00:00	185	2.210	
5	22-Apr-20	0:00:00	22-Apr-20	0:00:00	0:00:00	0	0.000	
6	22-Apr-20	5:45:15:30	22-Apr-20	9:00:24:00	11:45:00	185	2.146	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		0.523	10.482	11.005
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		44.029	75.438	119.467
PREVIOUS DAY ACTUAL RUNNING HOURS		14:00:00	57:25:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	98:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	95:00:00	

SSP hydrological data : at 08:00 Hrs on 23-Apr-20

DATA RECEIVED FROM FLOOD CELL

- . RESERVOIR LEVEL IN Metres 121.41 Mtrs.
- . AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 25507 Cusec 62 MCM
- . AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 27873 Cusec 68 MCM
- . GOG WATER REQUIREMENT (Next Day) in Cusec

HR	GODBOLE
2547	0

- . AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	2561	3289	24584	595



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-1, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Nil

AEE (EMC)
NCA, INDORE