

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 24-Apr-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 23-Apr-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	23-Apr-20	0:00:00	23-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 24.04.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
2	23-Apr-20	0:00:00	23-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	23-Apr-20	0:00 17:30	23-Apr-20	9:00 24:00	15:30:00	38.00	0.572	
4	23-Apr-20	0:00:00	23-Apr-20	0:00:00	0:00:00	0.00	0.000	
5	23-Apr-20	0:00:00	23-Apr-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	23-Apr-20	0:00:00	23-Apr-20	24:00:00	24:00:00	182	4.236	Today(i.e. 24.04.2020), 4 SSP-RBPH M/cs are running at 10:00 hrs.
2	23-Apr-20	0:00:00	23-Apr-20	24:00:00	24:00:00	183	4.218	
3	23-Apr-20	0:00 19:15	23-Apr-20	10:00 24:00	15:00:00	183	2.646	SSP RBPH Unit no. 5 will not be available due to penstock gate problem.
4	23-Apr-20	0:00 19:35	23-Apr-20	10:00 24:00	14:25:00	183	2.554	
5	23-Apr-20	0:00:00	23-Apr-20	0:00:00	0:00:00	0	0.000	
6	23-Apr-20	0:00 19:20	23-Apr-20	16:00 24:00	20:40:00	183	3.664	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)		0.572	17.318	17.890
CUMMULATIVE GROSS GEN. FOR MONTH (MUS)		44.601	92.756	137.357
PREVIOUS DAY ACTUAL RUNNING HOURS		15:30:00	98:05:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	95:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	49:15:00	

SSP hydrological data : at 08:00 Hrs on 24-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 121.17 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 12386 Cusec 30 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 29567 Cusec 72 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2547	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	2788	2698	26869	591



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
GoMP. Member(Power),NVDA,Bhopal
GoMah. CE,WRD, Mumbai
GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Nil

AEE (EMC)
NCA, INDORE