

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 25-Apr-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 24-Apr-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	24-Apr-20	0:00:00	24-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 25.04.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
2	24-Apr-20	0:00:00	24-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	24-Apr-20	0:00:16:00	24-Apr-20	5:00:24:00	13:00:00	37.00	0.469	
4	24-Apr-20	0:00:00	24-Apr-20	0:00:00	0:00:00	0.00	0.000	
5	24-Apr-20	0:00:00	24-Apr-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUS	REMARKS
1	24-Apr-20	0:00:5:15	24-Apr-20	2:30:10:00	7:15:00	174	1.234	Today(i.e. 25.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs. SSP RBPH Unit no. 5 will not be available due to penstock gate problem.
2	24-Apr-20	0:00:5:30	24-Apr-20	2:15:10:15	10:15:00	171	1.694	
3	24-Apr-20	0:00:20:45	24-Apr-20	14:00:24:00	17:45:00	171	2.932	
4	24-Apr-20	0:00:20:00	24-Apr-20	14:15:24:00	18:15:00	171	3.046	
5	24-Apr-20	0:00:00	24-Apr-20	0:00:00	0:00:00	0	0.000	
6	24-Apr-20	0:00:20:30	24-Apr-20	14:30:24:00	18:00:00	173	3.032	

	CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUS)	0.469	11.938	12.407
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)	45.070	104.694	149.764
PREVIOUS DAY ACTUAL RUNNING HOURS	13:00:00	71:30:00	
TODAY'S DC (Schedule) Planned (in Hours)	24:00:00	49:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)	24:00:00	26:00:00	

SSP hydrological data - at 08:00 Hrs on 25-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.95 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 5719 Cusec 14 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 21425 Cusec 52 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
2788	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	2988	3269	18156	585



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.

GoMP. Member(Power),NVDA,Bhopal

GoMah. CE,WRD, Mumbai

GoG CE(E&M),SSNNL,Vadodra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRDLC respectively. The details:

Unit No.1: 17:10 hrs on 24.04.2020 to 04:35 hrs on 25.04.2020