

DAILY PLANT REPORT (DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 26-Apr-20

ISSUE TIME: 10:00 Hrs

FOR DATE: 25-Apr-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	25-Apr-20	0:00:00	25-Apr-20	0:00:00	0:00:00	0.00	0.000	Today (i.e. 26.04.2020), 0 SSP- CHPH M/cs are running at 10:00 hrs.
2	25-Apr-20	0:00:00	25-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	25-Apr-20	0:00:00 17:00	25-Apr-20	7:00 24:00	14:00:00	37.00	0.512	
4	25-Apr-20	0:00:00	25-Apr-20	0:00:00	0:00:00	0.00	0.000	
5	25-Apr-20	0:00:00	25-Apr-20	0:00:00	0:00:00	0.00	0.000	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	25-Apr-20	5:30 21:30	25-Apr-20	8:45 24:00	5:45:00	165	0.936	Today (i.e. 26.04.2020), 0 SSP- RBPH M/cs are running at 10:00 hrs.
2	25-Apr-20	0:00 5:15 21:45	25-Apr-20	2:15 8:30 24:00	7:45:00	165	1.270	
3	25-Apr-20	0:00 5:00	25-Apr-20	2:30 8:15	5:45:00	167	0.942	
4	25-Apr-20	0:00 19:15	25-Apr-20	8:00 24:00	12:45:00	167	2.090	
5	25-Apr-20	18:45:00 0:00	25-Apr-20	24:00:00 2:45	5:15:00	163	0.852	
6	25-Apr-20	4:45 19:00	25-Apr-20	9:00 24:00	12:00:00	168	1.968	

					CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)					0.512	8.058	8.570
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)					45.582	112.752	158.334
PREVIOUS DAY ACTUAL RUNNING HOURS					14:00:00	49:15:00	
TODAY'S DC (Schedule) Planned (in Hours)					24:00:00	26:00:00	
DAY AHEAD (TOMMORROW) DC (in Hours)					24:00:00	28:15:00	

SSP hydrological data : at 08:00 Hrs on 26-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.90 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 10972 Cusec
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 14093 Cusec
- GOG WATER REQUIREMENT(Next Day) in Cusec 34 MCM

HR	GODBOLE
2988	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	3034	3282	10811	581



Copy to :

AEE (EMC)
NCA, INDORE

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA, INDORE.

GoMP. Member(Power), NVDA, Bhopal

GoMah. CE, WRD, Mumbai

GoG. CE(E&M), SSNNL, Vadoadra

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 KV SSP Asoj, Kasor, Dhule-1, Raj-2 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Nil