

DAILY PLANT REPORT(DPR) OF SARDAR SAROVAR PROJECT POWER HOUSES
(ENERGY MANAGEMENT CENTRE, INDORE)

ISSUE DATE: 27-Apr-20
ISSUE TIME: 10:00 Hrs
FOR DATE: 26-Apr-20

Daily Plant Report
(00:00 Hrs to 24:00Hrs.)

(CHPH 5X50 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	26-Apr-20	0:00:00	26-Apr-20	0:00:00	0:00:00	0.00	0.000	Today(i.e. 27.04.2020), 0 SSP-CHPH M/cs are running at 10:00 hrs.
2	26-Apr-20	0:00:00	26-Apr-20	0:00:00	0:00:00	0.00	0.000	
3	26-Apr-20	0:00:00	26-Apr-20	9:00:00	9:00:00	37.00	0.324	
4	26-Apr-20	0:00:00	26-Apr-20	0:00:00	0:00:00	0.00	0.000	
5	26-Apr-20	17:00:00	26-Apr-20	24:00:00	7:00:00	38.00	0.261	

(RBPH 6X200 MW)

Unit No.	START		STOP		RUNNING HRS	Max. LOAD (MW)	GENERATION IN MUs	REMARKS
1	26-Apr-20	0:00:5:15	26-Apr-20	1:30:7:30	3:45:00	162	0.618	Today(i.e. 27.04.2020), 0 SSP-RBPH M/cs are running at 10:00 hrs.
2	26-Apr-20	0:00:5:30	26-Apr-20	1:45:7:45	4:00:00	163	0.656	
3	26-Apr-20	5:45:22:15	26-Apr-20	8:00:24:00	4:00:00	163	0.654	
4	26-Apr-20	0:00:00:00	26-Apr-20	1:15:00:00	1:15:00	163	0.204	
5	26-Apr-20	0:00:22:30	26-Apr-20	1:00:24:00	2:30:00	165	0.400	
6	26-Apr-20	6:00:5:00:18:45	26-Apr-20	2:00:8:15:24:00	10:30:00	164	1.716	

		CHPH (5 X 50MW)	RBPH (6X200 MW)	SSP(CHPH+RBPH)
GROSS GENERATION IN(MUs)		0.585	4.248	4.833
CUMMULATIVE GROSS GEN. FOR MONTH (MUs)		46.167	117.000	163.167
PREVIOUS DAY ACTUAL RUNNING HOURS		16:00:00	26:00:00	
TODAY'S DC (Schedule) Planned (in Hours)		24:00:00	27:15:00	
DAY AHEAD (TOMMORROW) DC (in Hours)		24:00:00	28:00:00	

SSP hydrological data : at 08:00 Hrs on 27-Apr-20

DATA RECEIVED FROM FLOOD CELL

- RESERVOIR LEVEL IN Metres 120.94 Mtrs.
- AVERAGE INFLOW/QUANTUM IN Cusec(24 Hrs). 14040 Cusec 34 MCM
- AVERAGE TOTAL/QUANTUM OUTFLOW IN Cusec(24 Hrs). 10497 Cusec 26 MCM
- GOG WATER REQUIREMENT(Next Day) in Cusec

HR	GODBOLE
3034	0

- AVERAGE OUT FLOW IN Cusec(24 Hrs)

GODBOLE	OVER FLOW	HR	CHPH	RBPH	Ev. Loss
0	0	3027	3519	6978	581



Copy to :

NCA Executive Member/Member (Power)/Member (Civil)/SE(EMC)/DD (Hydromet), NCA,INDORE.
GoMP. Member(Power),NVDA,Bhopal
GoMah. CE,WRD, Mumbai
GoG CE(E&M),SSNNL,Vadoadra

AEE (EMC)
NCA, INDORE

NOTE : All the data are based on 24 Hrs average. All Gen. data are gross gen. and may be lesser in WRPC REA.

1. 400 kV SSP Asoj, Kasor, Dhule-2, Raj-1 lines are in service.

2. SCO Mode Running Detail:

RBPH Unit run in synchronous condenser mode to control high voltage condition as per instruction of WRLDC respectively. The details:

Unit No.1: 17:45 hrs on 26.04.2020 to 04:35 hrs on 27.04.2020

Unit No.2: 17:55 hrs on 26.04.2020 to 04:40 hrs on 27.04.2020